

PRODUCT PERFORMANCE REPORT

Document ID 1541057300

Issued on November 1st, 2018

PROJECT IDENTIFICATION

- This product performance report is delivered for:

Name **me**
Project reference **none**
Project location **Bulgaria**

PRODUCT IDENTIFICATION

Certification Diploma N° **94.01.077**
Brand **PANASONIC**
Range **2017**
Product type **Comfort Air Conditioners / up to 12 kW / Air cooled / Split / Reverse cycle**
Product reference **CU-DE35TKE-1 / CS-DE35TKE-1**

Important notice:

I. Data featured in this report are valid at the date of issue. The scope of this product performance report does not include all certified data that can be checked at <http://www.eurovent-certification.com>

II. This product performance report is valid only for above product features and should not be referred to as a Diploma.

FEATURE	VALUE	UNIT
Acoustic		
LwO env	64	dB(A)
Lw1 env	54	dB(A)
Bivalent Point		
Tbiv	-10	°C
COP @ Tbiv	2.31	
Ph TBiv	2.4	kW
General		
Mounting	W	
MPS	230-1-50	
Refrigerant	R410A	
Refr. Line	5 m	m
Heating 14511		
Ph @+7	3.84	kW
COP @+7	3.69	
Heating Average Climate		
Pdesignh	2.4	kW
SCOP	4	
SCOP Class	A+	
Qhe	840	kWh/annum
Poffc		
Poff	1	W
Psb		
Psb	1	W

PRODUCT PERFORMANCE REPORT

Document ID 1541057300

Issued on November 1st, 2018

FEATURE	VALUE	UNIT
Ptoc		
Pto	29	W
Seasonal Efficiency in Cooling		
Pdesignc	3.4	kW
SEER	5.6	
SEER Class	A+	
Qce	213	kWh/annum
Thermal		
EER @+35	3.06	
TOL Runing Test		
TOL	-15	Å, Å°C
COP @ TOL	1.98	
Ph @ TOL	1.84	kW