

Manual

For Operation



UCS 500Nx

The ultra-compact simulator
and its system modules

UCS 500 N5
UCS 500 N7

Modules for Telecom surge
Tsurge5 / Tsurge7
CNT 508 / CNT 516
V 4780 / V4780 S1

UCS500Nx - designed as a modular system - is the most intelligent solution offering exactly what you need for full-compliant immunity tests against transient and power fail phenomena. The distinct operation features, convenient DUT connection facilities, a clearly arranged menu structure and display philosophy as well as the pre-programmed standard test routines make testing easy, reliable and safe. Extendable by a variety of test accessories the UCS 500Nx is a universal equipment for a broad range of recommendations even for three-phase applications up to 100A

EN/IEC 61000-4-4
EN/IEC 61000-4-5
EN/IEC 61000-4-8
EN/IEC 61000-4-9
EN/IEC 61000-4-11
EN/IEC 61000-4-12
EN/IEC 61000-4-29
EN 61000-6-1
EN 61000-6-2



EM Test (Switzerland) GmbH

Sternenhofstrasse 15
4153 Reinach BL1
Switzerland

Phone : +41 61 717 91 91
Fax : +41 61 717 91 99

URL : <http://www.emtest.com>

Copyright © 2016 EM Test (Switzerland) GmbH

All right reserved.
Information in earlier versions. Specifications subject to change

Contents

1.	Model Overview	6
1.1.	UCS Models.....	6
1.2.	Standards covered by UCS N Series	8
2.	Safety information	9
2.1.	Protected Earth PE	9
2.2.	FI Fault current protection	9
3.	Operating Functions	10
3.1.	Front view	10
3.2.	Rear view	12
4.	Operation	15
4.1.	Description of the menus	15
4.2.	Menu structure	15
4.3.	Main Menu	16
4.4.	Service	17
4.5.	Setup	19
4.6.	Setup procedure for Set voltage	21
5.	Test Equipment UCS 500N	22
5.1.	UCS 500 N5.....	22
5.2.	UCS 500 N7.....	23
6.	Technical data	24
6.1.	EFT Electrical Fast Transients Burst as per IEC 61000-4-4	24
6.2.	SURGE Immunity requirements as per IEC 61000-4-5	25
6.3.	Power Fail Generator as per IEC 61000-4-11	26
6.4.	RINGWAVE Immunity requirements as per IEC 61000-4-12.....	27
6.5.	Telecom Surge Generator as per IEC 61000-4-5 (TSurge module)	28
6.6.	EUT Supply Specifications	29
6.7.	General Specifications	30
6.8.	Environmental conditions	30
6.9.	Technical data of special generators.....	31
6.9.1.	UCS 500N5.2T	31
6.9.2.	UCS 500N5.5 and UCS 500N5.6 and UCS 500N5.9 for Railways application.....	32
6.9.3.	UCS 500N5.11	33
6.9.4.	UCS 500N6.5.....	34
6.9.5.	UCS 500N6.7.....	34
6.9.6.	UCS 500N7.1.....	35
6.9.7.	UCS 500N7.4.....	35
7.	Maintenance setup and service	36
7.1.	General	36
7.2.	Test set- up.....	36
7.3.	Fuse for the EUT power supply	36
7.4.	Insulating- or external transformer for EUT power supply.....	36
7.5.	Calibration and verification	37
7.5.1.	Factory calibration	37
7.5.2.	Guideline to determine the calibration period of EM Test instrumentation	37
7.5.3.	Calibration of Accessories made by passive components only:	37
7.5.4.	Periodically In-house verification	37
8.	Delivery Groups.....	38
8.1.	Basic equipment	38
8.2.	Accessories and options.....	38

9.	EFT Burst as per IEC 61000-4-4	40
9.1.	Operation	40
9.1.1.	Quick Start	41
9.1.2.	Standard test routines	42
9.1.3.	User Test Routines	43
9.2.	Burst generation	45
9.3.	Test level with Burst as per IEC 61000-4-4 Ed.2.	45
9.4.	Coupling/decoupling network	46
9.4.1.	Coupling/decoupling network for ac/dc power lines	46
9.4.2.	Capacitive coupling clamp	46
9.5.	Burst Test Setup	46
9.5.1.	Test setup with capacitive coupling clamp	47
10.	Surge Immunity as per IEC 61000-4-5	48
10.1.	Operation	48
10.1.1.	Quick Start	49
10.1.2.	Standard test Routine	50
10.1.3.	User Test Routines	52
10.1.4.	Phase synchronization in 3-phase system	54
10.1.5.	Pulsed magnetic field as per IEC 61000-4-9	56
10.1.6.	Setup current limiter for surge current	57
10.1.7.	Charging time for surge	58
10.2.	Surge pulse generation	59
10.3.	Coupling/decoupling network	59
10.3.1.	Coupling to ac/dc power supply lines	59
10.3.2.	Coupling to I / O lines	60
10.4.	Test set-up	60
11.	Voltage Dips as per IEC 61000-4-11	61
11.1.	Test setup for DIPS and Interruption tests	61
11.2.	Operation	61
11.2.1.	Quick Start	62
11.2.2.	Standard Test Routines	63
11.2.3.	User Test Routines	67
11.3.	The Power Fail Test	68
11.4.	Overcurrent	69
11.5.	The Power Fail Test	70
11.5.1.	Voltage Interruptions	70
11.5.2.	Voltage dips, voltage variations	71
11.6.	DC Power networks	71
11.7.	Test setup and accessories	72
11.7.1.	Transformer type V4780	72
11.7.2.	Motor variac type MV 2616	74
11.8.	50/60Hz Magnetic Field as per IEC 61000-4-8	76
12.	Ringwave Immunity as per IEC 61000-4-12	78
12.1.	Operation	78
12.1.1.	Quick Start	78
12.2.	Ring wave pulse generation	80
12.3.	Coupling/decoupling network	80
12.3.1.	Coupling to ac/dc power supply lines	80
12.4.	Test set-up	80
13.	Telecom Surge	81
13.1.	UCS 500N5T with Telecom Surge Module	81
13.2.	TSurge7 Module	81
13.3.	TSurge7 Module	81
13.4.	TSurge Menu	82
13.4.1.	Quick Start	82
13.5.	Coupling Network	83
13.6.	Test Setup	84
13.7.	Test pulses TSurge Modules	84
13.7.1.	Waveshape Definitions according IEC 61000-4-5 Ed 3.0	84
13.7.2.	Pulse 10 / 700µs as per IEC 61000-4-5	85
13.7.3.	Pulse 9 / 720µs as per FCC	85

14. Appendix	86
14.1. Declaration of CE-Conformity	86
14.1.1. Declaration of Conformity UCS 500N5	86
14.1.2. Declaration of Conformity UCS 500N7	87
14.1.3. Declaration of Conformity UCS 500N5x models for one phenomenon	88
14.1.4. Declaration of Conformity UCS 500N5x models	89
14.1.5. Declaration of Conformity TSurge 7 Module for UCS 500N7	90
14.1.6. Declaration of Conformity CNT 516	91
14.1.7. Declaration of Conformity Tapped Transformer	92
14.2. UCS 500N - General Diagram	93
14.3. Main diagram control connection	93
14.4. Main diagram high voltage connection	94
14.5. CNT 508N	95
14.6. CNT 516	97
14.7. USB interface	99

1. Model Overview

The following manual is based on the following or later firmware:

- UCS 500N5 : V 5.00xx
- UCS 500N7 : V 8.00xx
- UCS 500N7 : V 9.00xx Supports ANSI A/B coupling method. Requires iec.control V 5.2.3.0 or higher

Devices with the Firmware

- UCS 500N5 : V 4.40uxx
- UCS 500N7 : V 7.40uxx

Have a reduced PFS function of the PFS module. For UCS generators with this firmware version exist a separate manual with the version 5.09. This manual can be ordered at EM TEST if required.

1.1. UCS Models

Standard models

Model	U pulse	CDN	Remarks		
UCS 500N5	5.5kV	300V	16A 1- ph		
UCS 500N5.1	5.5 kV	300V	32A 1- ph	Optional + Tsurge	6HU
UCS 500N5T	5.5 kV	300V	16A 1- ph	EFT, Surge, PFS, TSurge	6HU
UCS 500N5.1T	5.5 kV	300V	32A 1- ph	EFT, Surge, PFS, TSurge	6HU
UCS 500N7	7kV	300V	16A 1- ph	DC 300V / 16A ANSI	
UCS 500N7.1	7kV	300V	32A 1- ph	DC 300V / 32A ANSI	9HU

Additional extensions

TSurge5	4kV	Built-in 10/700us pulse module up to 5kV,	ITU K22 & IEC 61000-4-5
TSurge7	6kV	External 10/700us pulse module up to 7kV,	ITU K22 & IEC 61000-4-5

UCS500N with one built in module

The device includes only one module Surge, Burst or Power Fail. The technical data are identical with the standard UCS500N5. An extension with additional modules is not possible.

UCS500N5V	5kV	UCS500 with Surge Module
UCS500N5E	5.5kV	UCS500 with EFT Burst Module
UCS500N5P	--	UCS500 with Power Fail Module

Module for UCS500N7

Module	Remarks
EFT/N7	Built-in 5.5kV BURST MODULE
VCS/N7	Built-in 7.0kV SURGE MODULE
PFS/N7	Built-in POWER FAIL MODULE 300 volts/ 16 amps. Mandatory for EUT power switch off
RWG/N7	Built-in Ring Wave Module 6 kV / 100 kHz, Ri =12/30 Ω as per ANSI (not available for UCS 500N7.1 or UCS 500N7.2)
RWG/N7.1	Built-in Ring Wave Module 6 kV / 100 kHz, Ri =12/30/50 Ω as per ANSI / UL 1741, No peak current measurement (display indicates = ---). (not available for UCS 500N7.1 or UCS 500N7.2)
TSurge7	External 10/700us pulse module up to 7.0kV, ITU K22 & IEC 61000-4-5

Special models

Model	V Pulse	CDN	Remarks	
UCS 500N5.2	5.5kV	400V	16A 1- ph	
UCS 500N5.2T	5.5kV	300V	16A 1- ph	UCS 500 with VCS/5 and Telecom Surge module
UCS 500N5.3	5.5 kV	400V	32A 1- ph	
UCS 500N5.3-PFS	5.5 kV	400V	32A 1- ph	UCS500 with Power Fail module 400V AC 32A (L-N)
UCS 500N5.4	5.5kV	300V	16A 1- ph	DC 300V 16A
UCS 500N5.5	5.5 kV	300V	32A 1- ph	EFT/5 and VCS/5 10Ω/40Ω for supply lines EN 50121-3-2:2007 (Railway)
UCS 500N5.6	5.5 kV	300V	32A 1- ph	EFT/5 VCS/5 and PFS/5 10Ω/40Ω for supply lines EN 50121-3-2:2007 (Railway)
UCS 500N5.7	5.5kV	300V	16A 1- ph	EFT/5 and VCS/5
UCS 500N5.8	5.5kV	300V	16A 1- ph	EFT/5 and PFS/5; 1ph CDN 300V/16A
UCS 500N5.9	5.5 kV	300V	16A 1- ph	10Ω /40Ω for supply lines EN 55121 (Railway)
UCS 500N5.10	5.5kV	690V	16A 1- ph	VCS/5 without built-in coupler
UCS 500N5.11	5.5kV	690V	16A 1- ph	EFT/5, VCS/5 / Tsurge
UCS 500N7.2	7kV	400V	16A 1- ph	EFT/N7, VCS/N7, PFS/N7 (ANSI)
UCS 500N7.3	7kV	300V	16A 1- ph	EFT/N7, VCS/N7, PFS/N7 (ANSI), RWG/N7.x
UCS 500N7.4	7kV	400V	16A 1- ph	EFT/N7, VCS/N7, PFS/N7, (ANSI), RWG/N7.x
UCS 500N7.6	7kV	690V	16A 1- ph	EFT/N7, VCS/N7.x, RWG/N7, without built-in coupler! AC Voltage 690V
UCS 500N7.7	7kV	690V		EFT/N7, VCS/N7.x, without built-in coupler! AC Voltage 690V(p-p)
UCS 500N7.8	7kV	400V	16A 1- ph	EFT/N7, RWG/N7.x (output impedance 12 and 25 ohm); (ANSI)
UCS 500N7.9	7kV	690V		EFT/N7, VCS/N7, RWG/7.x (Ri 12Ω & 50Ω), no built-in coupler, 690V(p-p)
UCS 500N7.10	7kV	690V		VCS/7, no built-in coupler! Application Voltage 690V(p-p)

Other models up to 2009

Model	Name up to 2008	Pulse voltage	CDN	
UCS 500 N4.1	UCS 500 M4 S1	4kV	250V	32A single phase
UCS 500 N6	UCS 500 M6B	6kV	250V	16A single phase
UCS 500 N6.1	--	6kV	250V	32A single phase
UCS 500 N6.3	--	6kV	480V	32A single phase

Models up to 2008

Model	Pulse voltage	CDN	
UCS 500	4kV	250V	16A single phase upgrade version
UCS 500 M4	4kV	250V	16A single phase
UCS 500 M6	6kV	250V	16A single phase
UCS 500 M6A	6kV	250V	16A single phase

Special models

Special models have the index UCS500Nx **Sx**. The difference to the standard models are: Voltage- and current ranges. The operation is the same as by the standard UCS equipment's.

Model	Pulse voltage	CDN	
UCS 500 M4 S1	4kV	250V	32A single phase
UCS 500 M4 S2	4kV	690V	16A single phase
UCS 500 M4 S3	4kV	690V	32A single phase
UCS 500 M4 S5	4kV	280V	16A single phase
UCS 500 M6 S2	6kV	690V	16A single phase ANSI

Model	Pulse	EUT	Modules
UCS 500 M6B S1	6kV	250V 32A	EFT/6, VCS/6 and PFS/6; 1ph CDN 250V / 32A (ANSI) module RWG/6 not available
UCS 500 M6B S2	6kV	690V 16A	EFT/6, VCS/6 and PFS/6; 1ph CDN 690V / 16A (ANSI) 480V dc module RWG/6 not available

1.2. Standards covered by UCS N Series

A fully equipped UCS 500N covers the following standards

		UCS 500	N5	N7
- IEC 61000-4-4	Burst		X	X
- IEC 61000-4-5	Surge		X	X
- IEC 61000-4-8	50/60Hz Magnetic Field		X	X
- IEC 61000-4-9	Pulse Magnetic Field		X	X
- IEC 61000-4-11	Voltage Dips Voltage Interruptions Voltage Variations for ac power mains supply		X	X
- IEC 61000-4-12	Ringwave			X
- IEC 61000-4-29	Voltage Interruptions Voltage Dips for dc power supply systems		X	X
- ANSI	Surge with 2Ω coupling			X
- ITU and ETS	Telecom Surge		(X)	(X)
- FCC	Part 68		(X)	(X)

2. Safety information



Attention

Before using this equipment, read the operating manual and the separate delivered **safety manual** carefully

2.1. Protected Earth PE

The protective conductor connection is established via the attached power cord and must not be interrupted under any circumstances.



DANGER

Check before connecting the power supply to the unit that the **grounding of the building supply is installed according to regulations**.

In the absence of an earth connection can the frame can be get in the event of a fault, to the mains voltage potential.

The generator must be properly grounded before connecting on-the EUT supply voltage to the generator.

2.2. FI Fault current protection

The standards recommend decoupling and filter capacitors to PE for decoupling surge pulses. This is the reason for tripping fault current protection relays interrupt the mains to the EUT supply. For eliminate the circumstance use one of the following options:

Remove the fault current protection


This solution does not limit the current to PE. The surge test as other EMC tests with higher currents to PE are possible. The user must take care to the circuit with no fault current protection. Only trained professional people are allowed to perform such tests.

Using of insulating transformers

An insulating transformer separates the circuit from the test circuit. The Fault current detector cannot detect the earth current in the EUT circuit. The synchronization works between line and PE and therefore a connection between neutral and PE is necessary. Without this N-PE connection the stray capacitance defines the phase sync.



The fault current safety detection function in the generator circuit is disabled. The user must respect this circumstance. For a safe operation he must follow the electrical rulers.



Behind the insulating transformer the neutral and PE must be connected for a proper phase synchronization of the generator. In case of a 3-phase system the user must perform similar.

3. Operating Functions

3.1. Front view



- | | | | | | |
|---|-------------------------|----|----------------------------------|----|-----------------------------------|
| 1 | Display | 6 | Exit | 11 | HV pulse Burst output 50 Ω |
| 2 | Function keys "F1..F7" | 7 | Escape | 12 | Ground reference |
| 3 | "Test On" | 8 | CRO U (surge) | 13 | Coupling (Burst, Surge and EFT) |
| 4 | Knob (Inc. / Dec | 9 | CRO I (surge) | 14 | Channel PF1 and PF2 |
| 5 | Cursor keys "←" and "→" | 10 | CRO Trigger output $\uparrow$ 5V | 15 | EUT test supply |

1 Display

All functions and parameters are displayed (8 lines with max. 40 characters).

2 Function keys "F1 .. F7"

Parameters and functions, displayed in the lowest line, can be selected with the related function key.

3 Test On

By pressing the key "Test On" follows the functions:

- Activate the high voltage power unit; HV is ready to start.
- Switches ON the supply to the EUT test supply (only with built in PFS module).
- The LED indicates the trigger of a burst event.

4 Knob (Inc. / Dec

The knob increments or decrements test parameters with a numeric value or selects from a list of parameters.

5 Cursor keys

Parameters and functions can be changed on-line. The selection of these parameters is realized with the cursor moving to the left or to the right.

6 Exit

Pressing of the Exit function will cause a reset of the firmware. This is only possible if no test routine is running.

7 ESC

When pressing the ESC button the user moves back one page in the menu.

8 CRO U (surge)

At the BNC output the voltage pulse (surge) of the generator can be measured galvanic separated.

- Impedance measuring instrument: $>1M\Omega$.
- Max. output voltage: 10V $\pm 10\%$ at 5 kV / 7kV impulse voltage.

9 CRO I (surge)

At the BNC output the current pulse (surge) of the generator can be measured galvanic separated.

- Impedance measuring instrument: $>1M\Omega$.
- Max. output voltage: 10V $\pm 10\%$ at 2.5 kA / 3.5kA output current.

10 BNC - CRO Trigger

At the BNC output the generator trigger can be checked, e.g. the burst duration, the burst repetition rate and the spike frequency (+5 V rectangular). This output can be generally used as oscilloscope trigger output and is synchronous to the following events.

- Burst and surge release
- Voltage dip or interruption, start of the event



- | | | | | | |
|---|-------------------------|----|----------------------------------|----|-----------------------------------|
| 1 | Display | 6 | Exit | 11 | HV pulse Burst output 50 Ω |
| 2 | Function keys "F1..F7" | 7 | Escape | 12 | Ground reference |
| 3 | "Test On" | 8 | CRO U (surge) | 13 | Coupling (Burst, Surge and EFT) |
| 4 | Knob (Inc. / Dec | 9 | CRO I (surge) | 14 | Channel PF1 and PF2 |
| 5 | Cursor keys "←" and "→" | 10 | CRO Trigger output $\uparrow$ 5V | 15 | EUT test supply |

11 HV pulse burst output 50 Ω

External coupling devices such as the capacitive coupling clamp and the 3-phase coupling network are connected to the coaxial 50 ohm output. Also the calibration of the generator is handled at this output.
Note: The burst signal is present on this output at every coupling mode.

12 Ground reference

During test or calibration procedure the burst generator must be grounded to the reference ground plane

13 Coupling mode

The actual coupling mode is indicated by LED

14 Channel PF1/PF2

This LED indicates the channel mode during the power fail test.

15 EUT test supply

For single-phase EUT the coupling/decoupling network is part of the generator. The EUT is powered via the safety banana plugs at the front panel of the simulator.

3.2. Rear view



- | | |
|--|-----------------------------|
| 1 Test supply input; channel PF1 together with the red lamp for phase indication | 3 Test supply input neutral |
| 2 Test supply input; channel PF2 together with the red lamp for phase indication | 4 Test supply input PE |
| | 5 Sync input |

1 Test supply PF1

The phase of the power supply for the EUT is connected to the banana connector PF1. The phase L is conducted to the EUT voltage supply via PF1 if channel PF1 is selected in the set-up menu.

To guarantee a correct function of the synchronization the phase shall be connected to this input. The red lamp than shall be alighted.

2 Test supply PF2

This input is generally used for the reduced dip voltage for testing as per IEC 61000-4-11. At this PF2 input a variac transformer is connected with a reduced voltage, e.g., 0-250V. A motor driven variac transformer can be controlled via a 0-10V analogue control output.

To guarantee a correct function of the synchronization the phase shall be connected to this input. The red lamp than shall be alighted.

3 Test supply neutral (PF1/PF2)

The neutral line of the power supply for the EUT is connected to the banana connector N.

4 Test supply PE (PF1/PF2)

The protective earth line of the power supply for the EUT is connected to the banana connector PE.

5 SYNC input

An ac voltage to which the events shall be synchronized is connected to this input. If no voltage is available the tests are started automatically in asynchronous mode. Normally this input shall be connected directly to L of the channel PF1. $U_{max. Sync} = U_{max. EUT}$

Connection EUT supply

AC Supply

The EUT power supply is normally connected to the UCS plugs PF1, N and PE

A tap of a motor variac transformer or adapting transformer for power fail testing is connected to the connection PF2.


The phase synchronization SYNC must be connected to PF1. By missing this connection all tests runs in asynchronous mode with no phase angle adjust for pulse release.

DC Supply

DC+ to PF1, and PF2 for DIPS

DC- to N

additional PE (depends application)



Earth bolt

The earth bolt must be connected to the ground reference.



- | | |
|---------------------------------|------------------------|
| 6 Reference Earth connection | 10 Warning lamp |
| 7 HV output for Surge pulse | 11 External trigger |
| 8 Common output for Surge pulse | 12 BNC connector MON U |
| 9 Ventilation | 13 BNC connector MON I |

6 Reference earth connection

The generator has to be connected to the reference earth plane of the test set up. The connection at the rear part of the generator is an alternative to the grounding point at the front panel

7 HV output

The coax plug is the HV HIGH output of the simulator. It is used for external coupling/decoupling networks.

8 COM output

The Com output is the HV LOW output of the simulator. The output is floating



Attention

The direct output of the surge generator is located at the rear panel of the instrument, HV and COM. It is not allowed to connect these outputs to any other coupling/decoupling network than manufactured by EM TEST, e.g. the types CNV and CNI. Before to connect any external networks to this output the operator must contact the manufacturer. Any damages due to this matter are not covered by warranty.

The direct pulse output shall also not be used to connect the generator directly to any power conducting lines

The wave shape measured at the direct pulse output must not be within the tolerances specified in IEC 61000-4-5. The pulse shape shall be verified at the CDN output directly, no matter whether it is an internal or external CDN.

9 Ventilation

After long term duration tests the generator should keep on running for some minutes to cool down the system.

10 Warning lamp

A voltage free contact is available for external warning indications (warning lamp). The signal is generated after pressing TEST ON.

11 External trigger

One single event, burst, surge, voltage dip or ESD can be released. Trigger level 5V positive going.

12 BNC connector MON U

At this BNC connector the output power supply voltage for the EUT can be measured. Ratio 100:1 $\pm$ 5%. Impedance measuring instrument: $\geq 1\text{M}\Omega$.

13 BNC connector MON I

At this BNC connector the output current for the EUT can be measured, e.g. the nominal current or the peak inrush current. The rating is 10mV/A $\pm$ 5%. Maximum current = 1000A. Impedance measuring instrument: $\geq 1\text{M}\Omega$.



14 Control output 0-10V

15 Security circuit

16 Mains selector 115V / 230V

17 Power on switch

18 Fuse of the high voltage power supply

19 Serial interface USB

20 Parallel interface IEEE

21 Remote control connector

22 FAIL 1

23 FAIL 2

14 Control output 0-10V

The voltage is used to control external power sources. The source is normally connected to the channel PF2 (normally a motor driven variac transformer). The voltage level is selectable via the operating facilities of the UCS 500N. The voltage level can also be selected within the service menu under the function „setup“. This output is not mounted on UCS500N5E and UCS500N5V.

15 Safety circuit

The test can only be started if the security circuit is closed. If the circuit is opened during a running test the simulator will be switched off immediately.

16 Mains selector

Selection of 115V / 230V

17 Power on switch

The switch is part of the mains filter. Mains fuses are part of the filter. (230V / 2 A and 115V / 4 A)

18 Fuse of the high voltage power supply

The high voltage power supply is protected by this fuse „F3“. In case that no high voltage is generated but the control unit works properly this fuse shall be checked.

19 USB interface

USB interface “USB B” connector. For data-transfer a USB interface is available. The internal RS 232 interface is converted to USB standard. Therefore the user must set the same baud-rate in the device and control software.

Using the USB interface may cause EMC problems during burst tests at the computer or notebook side of the communication line. Therefore a high quality USB cable (USB 2.0 standard) shall be used.

20 Parallel interface GPIB / IEEE 488

IEEE 488 interface with IEEE connector

21 Remote control connector CN

External coupling devices are controlled via this remote control connector.

22 Fail detection FAIL 1 EUT control (TEST STOP)

Grounding this input will cause a complete stop of the running test procedure. (+15V to ground) The test must be completely restarted.

23 Fail detection FAIL 2 EUT control (TEST PAUSE)

Grounding this input will cause a break for the running test procedure (+15V to ground). The test will be continued when the input is no more connected to ground.

4. Operation

4.1. Description of the menus

The simulator is operated by an easy menu control system. Seven function keys are available to select parameters and functions. All functions are indicated on the display; max. 8 lines and 40 characters.



The selected parameter is blinking and can be changed by turning the knob (inc./dec.).

↔ : The digit for change can be selected with the cursor (↔).

- Selected values are direct indicated on the screen.

- Status on the bottom lines shows the desired status after pressing the function key.

ESC : ESC will take you back to the previous level in the menu and set the displayed values. The latest settings are stored automatically and will be recalled when the menu is selected again.

EXIT : The firmware will reset to the main screen.

EM TEST	Burst Surge Power Fail
UCS 500 N5	
Ultra Compact Simulator	
V 5.00a02	SWN: 001234

The serial number and the version number SWN are used for traceability reasons. These numbers are listed in the test reports and calibration certificates. These numbers also are listed within the test reports generated by the iec.control software.

Start-up display example UCS 500N5. The models type is displayed after startup.

4.2. Menu structure

Level 0...4

Level 0	Level 1	Level 2	Level 3	Level 4
MAIN MENU F1 BURST IEC 61000-4-4 F2 SURGE IEC 61000-4-5/9 F3 PFS IEC 61000-4-11/8/29 F7 SERVICE	Burst IEC 61000-4-4 F1 Quick Start F2 Standard routines F3 User test routines	Quick Start F1 Start F2 Change F3 Continue	Start Start the test routine Change Select all parameters Continue Continue the test routine	
	Surge IEC 61000-4-5/9	Standard routines Preprogrammed test routines as per standard requirements	Standard routines F1 : F4 IEC 61000-4-4 Level 1-4 F5 Generic Standard EN 61000-6-1 F6 Generic standard EN 61000-6-2 F7 Manual standard routine	Standard routines F1..F3 F1 Start F2 Change F3 Continue
	Power Fail IEC 61000-4-8/11/29	User test routines Preprogrammed test routines for evaluation and design support	F1 Synchronous to the mains F2 Random burst release F3 Change V after T by ΔU F4 Frequency sweep I F5 Frequency sweep II F6 Frequency sweep III F7 Change polarity after T	User test routines F1..F3 F1 Start F2 Change F3 Continue
	Service F1 Addresses F3 Setup F4 Change standard levels	Setup F1 Change language F2 LCD backlighting F3 Interfaces F4 ESD/keyboard beeper F5 Running time clock F6 Set voltage F7 Magnetic field factors	Change language Germ or English LCD backlighting On, Off or Auto Interfaces Select all parameters ESD/keyboard beeper (on, off) Running time clock Display of the TEST ON time Set voltage (ext. motor variac) Magnetic field factors Correction factors for magnetic field antenna and current transformer	
		Change standard level	Change standard level F1 All parameters to standard level F2 IEC 61000-4 F3 EN 61000-6-1 F4 EN 61000-6-2	Change standard levels F1 IEC 61000-4-4 Burst F2 IEC 61000-4-5 Surge ...

4.3. Main Menu

MAIN MENU	
F1 : Burst	IEC 61000-4-4
F2 : Surge	IEC 61000-4-5/9
F3 : Power Fail	IEC 61000-4-11/8/29
F4 : Ringwave	IEC 61000-12
F5 : TSurge	
F7 : Service	
F1	F2
F3	F4
F5	F6
F7	

F1 Burst test

With function key F1 the user can select Burst Test as per **IEC 61000-4-4**. The test pulses are fast transients with a pulse shape of 5/50ns.

Attention: The generator covers the new specifications given in the draft revision IEC 61000-4-4 edition 2. This means a new spike frequency which is selectable between 5 kHz and 100 kHz. The burst duration is automatically matched between 15ms and 0.75ms. The common mode coupling is new with all couplings at the same time.

F2 Surge test

With function key F2 the user can select Surge Test as per **IEC 61000-4-5**. The test pulses are high energy pulse with a voltage shape of 1,2/50 μ s and a short circuit current shape of 8/20 μ s.

In addition the test procedure for Pulse Magnetic Field testing as per **IEC 61000-4-9** is included in this menu.

F3 Power Fail test

With function key F3 the user can select the Power Fail Test as per **IEC 61000-4-11**.

The simulator will generate voltage dips and voltage variations with preselectable parameters. **IEC 61000-4-11** is valid for ac power supply systems. For dc supply system in future **IEC 61000-4-29** shall be recommended.

In addition the test procedure for 50/60Hz Magnetic Field Testing as per IEC 61000-4-8 is included within the menu.

The Power fail menu includes a **Voltage Variation** test as per IEC 61000-4-11 as test procedure. The simulator will generate voltage variations in the second range.

Attention: The generator covers already the new specifications given in FDIS IEC 61000-4-11: 2004. This means the introduction of a new 80% test level as well as a new function for the Voltage Variation test.

F4 Ringwave as per IEC 61000-4-12 (UCS500 N7)

With function key F4 the user can select the Ring Wave Test as per **IEC 61000-4-12** or **ANSI/IEEE**. The test pulses are single-shot with an oscillating and decaying waveshape.

F5 Telecom Surge Test

With the Option TSurge a Telecom Surge pulse 10/700 μ s as per IEC 61000-4-5, ITU, ETS or FCC part 68 Pulse B is available.

F7 Service

Setup and servicing routines are available.


4.4. Service

SERVICE						
F1 : Addresses						
F3 : Set-up						
F4 : Change standard levels						
F7 : Status						
F1	F2	F3	F4	F5	F6	F7

F1 Addresses

The addresses of the EM TEST (Switzerland) GmbH and the EM TEST GmbH are shown. The addresses of all EM TEST sales agencies are listed on the web site of EM Test under :

www.emtest.com



F3 Set-up

The software will clearly explain the set-up procedure.

F4 Change standard levels

The stored standard test levels can be changed within this menu.

SERVICE Change standard levels						
F1 : Reset all standard levels						
F2 : IEC 61000-4						
F3 : EN 61000-6-1						
F4 : EN 61000-6-2						
F1	F2	F3	F4	F5	F6	F7

The user can change the stored standard levels

F1: Set all parameters acc. to standard. The stored standard test levels can be changed within this menu.
The settings are actualized to the standards dated in summer 2004.

F2: IEC 61000-4

F1: IEC 61000-4-4	Burst
F2: IEC 61000-4-5	Surge
F3: IEC 61000-4-8	Magnetic field AC
F4: IEC 61000-4-9	Magnetic field Surge
F5: IEC 61000-4-11	Power Fail AC
F6: IEC 61000-4-29	Power Fail DC

F3: EN 61000-6-1 Generic

F1: EN 61000-6-1	Generic Burst
F2: EN 61000-6-1	Generic Surge
F3: EN 61000-6-1	Generic Power Fail

F4: EN 61000-6-2 Generic

F1: EN 61000-6-1	Generic Burst
F2: EN 61000-6-1	Generic Surge
F3: EN 61000-6-1	Generic Power Fail

F7 Status

Status information of the equipment.

UCS500N5 UCS500N7**Page 1**

UCS500N5 V5.00 005000	Built in Modules
Operating 00000035.53 hrs Test time 00000015.53 hrs	DI-Status 0000 SCR-Status 0000

Model Version SW Number	Burst Surge Power Fail	Ringwave Int. 1Ph
Information of operating		Status information

Page 2

Keyboard Beep off	RS 232 19200
Countdown Beep off	IEEE 15
Backlighting 5 min	
DAC adjust Voltage	H-field
+0, +0 V 264	Af
+0, +0 Vn 230	Tf
+0, +0 CH PF1	If

Setup information	Interface information	
DAC Adjust	Parameter Set voltage	H-filed parameter

4.5. Setup

SETUP						
F1 : Change language / Sprache ändern						
F2 : LCD backlighting						
F3 : Interfaces						
F4 : Beep						
F5 : Timer						
F6 : Set voltage						
F7 : Magnetic field correction factors						
F1	F2	F3	F4	F5	F6	F7

Firmware V 6.01ax (UCS 500N5) V9.04ax (N7x)

SETUP						
F1 : Change language / Sprache ändern						
F2 : LCD backlighting						
F3 : Interfaces						
F4 : Beep						
F5 : Timer						
F6 : Set voltage low / high						
F7 : Magnetic field correction factors						
F1	F2	F3	F4	F5	F6	F7

F1 Change language

The user can chose between two languages, German and English.

F2 LCD backlighting

With the use of F2 the backlighting can be switched on or off.

Additionally the **Auto Off** function can be programmed to switch off the backlighting after a defined time that the equipment has not been in operation (1 - 30min). Because of the limited lifetime of LCD displays, approx. 10,000h this function should always be activated.

F3 Interfaces

This menu will help the user to define the status of the integrated serial and parallel interfaces, e.g. the baud rate of the RS 232 or the address of the IEEE interface.

F4 Beep

F1 is the selector for the keyboard beeper ON/OFF mode. (Short beep at every keyboard hit)

F3 is the selector for the countdown-beeper ON/OFF mode. (Short beep before surge pulse releasing)

To indicate that a running test is finished the beeper sounds always 3 times (not changeable).

F5 Operating time

Pressing of F5 will show the different operating time and status of the test equipment.

Operating time: Total time where the UCS is powered on.

Testing Time: Total time during a running test.

DI – Status: Service information about internal digital inputs.

SCR – Status: Service information about surge switch operation

F6 Set voltage low/high Firmware V 6.01ax (UCS 500N5) V9.04ax (N7x)

This Firmware version offers **two separate voltage settings** for user that needs to test equipment for 115 V and 230V mains supply. Thanks to the two settings, the user can keep the Motorvariac in the 230V position

Using a MV 2616 with voltage selector switch:

- Set the voltage selector to the 230V position for low and high mains voltage supply.
- Use the Firmware with low and high settings and use the MV 2616 for any supply in the 230 V position.

The operator can specify the following parameters:

- | | |
|---|---|
| F1: Setup Main Voltage to low 115 V. | Motorvariac parameter settings for lower main voltage. (115 V) |
| F2: Setup Main Voltage to high 230 V | Motorvariac parameters for higher main voltage. (230 V) |
| F3: Motorvariac high (low) | Selection and indicate of the active "Main Voltage" setting. The selected setting is used in the power Fail tests for motorvariac control |

The procedure for low and high parameters voltage setting is the same as described in F6 Set Voltage below.

F6 Set voltage

For control of an external power supply source an analogue control voltage can be programmed (0-10V dc).

The operator can specify the following parameters:

- F1: Max. variac voltage V [V]** Maximal output voltage at 100% position of the external motor variac or dc controlled voltage source. The analogue reference value for the max. voltage is 10 V.
- F2: Mains supply voltage V [V]** of the device under test. This voltage shall be specified by the operator and depends on the type of equipment under test. The variac normally is automatically set to this output voltage.
- F3: Default channel.** The operator select the default channel PF1 or PF2 from which the EUT is powered.

F7 Magnetic field correction factors

F1: Coil factor	Af [A/m]	Range [0.200...9.99	step 0.01]
F2: Transformer factor	Tf [A/V]	Range [0.020...9.999	step 0.001]
F3: Impedance factor	If [A/V]	Range [0.200...1.00	step 0.01]


These values are delivered together with the necessary options to conducted magnetic field testing.

- Coil factor depends on the type of antenna which is used for the test.
- Transformer factor depends on the type of transformer which is used for the test.
- Impedance factor depends on the type of surge generator which is used for the test. A generator with a source impedance of 2Ω needs an impedance factor of approx. $I_f = 0.5$

5. Test Equipment UCS 500N

The simulator UCS 500N is separated in different main parts. The control unit is screened to all other parts.

5.1. UCS 500 N5



Control unit

- 1 Power supply board
- 2 Interface board
- 3 Controller board
- 4 Power supply transformer

High voltage unit

- 9 High voltage power supply
- 10 Storage capacitor
- 11 HV- board
- 12 ESD controller board
- 13 Surge switch-board

Coupling/decoupling unit

- 18 Filter board
- 19 Decoupling chokes
- 20 Coupling/decoupling network

- 5 Filter board / connecting board
- 6 Keyboard / LCD- display
- 7 General power supply input, filter
- 8 Ventilation

- 14 Coupling capacitors for surge mode
- 15 High voltage switch for burst mode
- 16 Power switches for voltage dip mode PF1, PF2
- 17 Current sensor

- 21 Measuring and control output
- 22 Input for the power mains supply of the EUT
- 23 Output for the EUT supply

5.2. UCS 500 N7



Control unit

- 1 Power supply board
- 2 Interface board
- 3 Controller board
- 4 Power supply transformer
- 5 Filter board / connecting board

High voltage unit

- 10 High voltage power supply
- 11 Surge/Burst storage capacitor
- 12 Ringwave storage capacitor
- 13 HV switching board

Coupling/decoupling unit

- 18 Surge/Ringwave coupling capacitors
- 19 Coupling network
- 20 Decoupling chokes

- 6 Keyboard / LCD- display
- 7 Measuring and control outputs
- 8 General power supply input, filter
- 9 Ventilation

- 14 Burst module
- 15 Surge module
- 16 Ringwave module
- 17 Power Fail module

- 21 Filter board for the EUT supply
- 22 Input for the EUT supply
- 23 Output for the EUT supply

6. Technical data

6.1. EFT Electrical Fast Transients Burst as per IEC 61000-4-4

Test Level	Model N5	Model N7
Open circuit *	200V - 5500V ± 10% Step 20V	200V – 5500V ± 10% Step 50V
Wave shape into a 50Ω load	100V – 2750V	100V – 2750V
Rise time tr	5ns ± 30%	5ns ± 30%
Pulse duration td	50ns ±30%	50ns ±30%
Wave shape into a 1000Ω load	200V – 5500V	200V – 5500V
Rise time tr	5ns ± 30%	5ns ± 30%
Pulse duration td	35ns - 150ns	35ns – 150ns
Source impedance	Zq = 50Ω ± 20%	Zq = 50Ω ± 20%
Polarity	Positive / negative	positive / negative
Trigger		
Trigger of bursts	AUTO, MANUAL, EXTERN	
Synchronization	0 - 360° (16 - 500Hz)	
	Asynchronous = 0° a reference signal is connected to the Sync input.	
Burst duration td	0.10ms – 999ms	
Burst repetition rate tr	10ms – 9999ms	
Spike frequency f	0.1kHz – 1000kHz	
	Range	Step
	< 10 kHz	0.1 kHz
	10 – 100 kHz	1.0 kHz
	100 – 250 kHz	10.0 kHz
	> 250 kHz	50.0 kHz
Test duration T	0:01 min - 99:59 min	
Output		
Direct via 50Ω coaxial connector	To connect ext. coupling devices	To connect ext. coupling devices
Coupling network	To L, N, PE all combinations	To L, N, PE all combinations
DUT power mains supply	AC 300 V / 16 A / 50/60 Hz	AC 300 V / 16 A / 50/60 Hz
	DC 300 V / 160 A	DC 300 V / 16 A
Test routines		
Quick Start	Immediate start, all parameters adjustable during a running test	
Standard test as per	IEC 61000-4-4 level 1 IEC 61000-4-4 level 2 IEC 61000-4-4 level 3 IEC 61000-4-4 level 4 EN 61000-6-1 Generic EN 61000-6-2 Generic IEC 61000- 4-4 Manual operated standard test routine	
User test routines	Synchronous burst release Random burst release Change level V after T by steps of dV Frequency sweep in one single burst Frequency sweep with constant pulses Frequency sweep, constant burst duration Change polarity after T	

* With Burst pulses as per. IEC 61000-4-4 Ed2 : 2004 the max. output voltage can be limited.

6.2. SURGE Immunity requirements as per IEC 61000-4-5

Test Level	Model N5		Model N7	
Open circuit voltage	160 V – 5000 V ± 10% Step 20 V		250 V – 7000 V ± 10% Step 50 V	
Short circuit current	80 A – 2500 A ± 10%		125 A – 3500 A ± 10%	
Wave shape open circuit				
coupling	18 µF line to line	9 µF line to ground	18 µF line to line	9 µF line to ground
Front time tr	1,2 µs ± 30%	1,2 µs ± 30%	1,2 µs ± 30%	1,2 µs ± 30%
Pulse duration (16A model)	50 µs +10 µs/-10 µs	50 µs +10 µs/-25 µs	50 µs +10 µs/-10 µs	50 µs +10 µs/-25 µs
Pulse duration (32A model)	50 µs +10 µs/-15 µs	50 µs +10 µs/-30 µs	50 µs +10 µs/-15 µs	50 µs +10 µs/-30 µs
Wave shape short circuit				
coupling	18 µF line to line	9 µF line to ground	18 µF line to line	9 µF line to ground
Front time tr	8 µs ± 20%	2.5 µs ± 30%	8 µs ± 20%	2.5 µs ± 30%
Pulse duration	20 µs ± 20%	25 µs ± 30%	20 µs ± 20%	25 µs ± 30%
Polarity	Pos., Neg., Alt		Pos., Neg., Alt	
Repetition rate	max. 1Hz (1s* - 999s)		max. 0.5Hz (2s* - 999s)	
Events preselection	1 - 30'000 or endless		1 - 30'000 or endless	
Counter	1 - 1000000		1 - 1000000	
Trigger				
Trigger of pulses	AUTO, MAN, EXTERN		AUTO, MAN, EXTERN	
Synchronization	0 - 360° (16 - 500Hz)		0 - 360° (16 - 500Hz)	
Synchronization	Asynchronous = 0°		a reference signal is connected to the Sync input.	
Resolution	1°		1°	
Measurements				
CRO	5 V Trigger		5 V Trigger	
CRO Ũ	10 Vp at 5 kV		10 Vp at 7.0 kV	
CRO Î	10 Vp at 2.5 kA		10 Vp at 3.5 kA ; ± 1 Digit ± 50 A	
Accuracy CRO U , CRO I	± 10%		± 10%	
CRO Ũ/I Z measuring instrument	> 1 MΩ		> 1 MΩ	
Peak voltmeter	5000 V		7000 V	
Peak current meter	2500 A : Display ± 1 Digit ± 20 A		3500 A : Display ± 1 Digit ± 50 A	
Current limiter setting	10 A...3000 A step 10 A		10 A...4000 A step 10 A	
Output			N5	N7
Direct	HV-Banana connector, Zi = 2 Ω		X	X
Coupling network	L – N with Z = 2Ω		X	X
	L-PE, N-PE, L+N-PE with Z = 12Ω		X	X
	L-PE, N-PE, L+N-PE with Z = 2Ω		na	X
DUT supply	AC 300V / 16A / 50/60 Hz		X	X
	DC 300V / 16A		X	X
Test routines				
Quick Start	Immediate start, all parameters adjustable during a running test			
Standard test routines as per	IEC 61000-4-5 level 1 IEC 61000-4-5 level 2 IEC 61000-4-5 level 3 IEC 61000-4-5 level 4 EN 61000-6-1 Generic EN 61000-6-2 Generic IEC 61000-4-5 Manual operated standard routine			
User test routines	Change polarity after n pulses Change coupling mode after n pulses Change voltage level V after n pulses by ΔV Change phase angle A after n pulses by ΔA			
Magnetic field test	test routine as per IEC 61000-4-9 test level 100, 300 and 1000A/m cont. adjustable within Quick Start			

* depends on charging voltage

6.3. Power Fail Generator as per IEC 61000-4-11

EUT supply	Model N5	Model N7
Channel PF1 and PF2		
AC voltage/current	max. 300V/16A	max. 300V/16A
Mains frequency	50/60 Hz	
DC voltage/current	max. 300V/16A	max. 300V/16A
Inrush current	more than 500A	
Protection	Electronic fuse for continuous overcurrent / inrush currents Electronic control of overheating PF1 and PF2 are safe against short circuit	
max. current channel PF1	nominal current continuous	
max. current channel PF2	nominal current with intermittently 10s (50% duty cycle)	
Trigger		
Events trigger	AUTO, MAN, EXTERN	
Repetition rate	0.01s – 9'999s	Accuracy 0.05% + phase sync
Duration of events	0.02ms – 9'999s	Accuracy 0.05%
Events preselection	1 - 30'000 or endless	1 - 30'000 or endless
Counter	1 - 1000000	1 - 1000000
Synchronization	0 - 360° (16 - 500Hz) Asynchronous = 0° if a reference signal is connected to the Sync input.	
Max Sync input voltage	Max. 300V or same as EUT voltage specs.	
Resolution	1°	
Measurements		
DUT supply	AC/DC voltage in the LCD display, divider ratio 1:100 +/- 10%	
BNC output MON U	Measurement of the EUT supply divider ratio 1:100 ± 5%	
BNC output MON I	Measurement of the EUT current and the inrush current 10mV/A ± 5%, max. 1000A	
CRO TRIGGER	positive going flank	
0-10V Control Output	0-10V DC for external voltage source	
Test routines		
Quick Start	Immediate start, all parameters adjustable during a running test	
Standard test routines	as per IEC 61000-4-11 ac power ports as per IEC 61000-4-29 dc power ports as per IEC 61000-6-1 Generic as per IEC 61000-6-2 Generic Manual operated standard test routine	
User test routines	Voltage variation, external variac control Change phase angle W after n events by dA Change events duration td after n events by dtd Inverse mode	
Magnetic field test	test routine according to IEC 61000-4-8 test level 1, 3, 10 and 30A/m with MC 2630 and a variac test level 100, 300 and 1000A/m with MC26100	

Magnetic field tests per IEC 61000-4-8 and -9

The test routines for handling the magnetic field tests are included in the internal UCS 500N firmware. All functions to control external options as voltage/current sources or magnetic field antennas are included. In addition the following hardware is required:

Option required for Magnetic Field Test per IEC 61000-4-9

- Magnetic field antenna (square 1mx1m coil MS 100)
- Adapter for connecting the square coil to the surge output.

Option required for Magnetic Field Test 50/60Hz per IEC 61000-4-8

- External variac (MV2616) and magnetic field antenna (square 1mx1m coil MS 100)
- External current transformer (MC2630) to test 1, 3, 10 and 30 A/m levels
- External current transformer (MC26100) to test level 100, 300 and 1000 A/m levels (short term).

6.4. RINGWAVE Immunity requirements as per IEC 61000-4-12

The Ringwave module is available for the UCS500 N7 generator.

Test level

Open circuit voltage	6000 V $\pm$ 10 %
Wave shape voltage	
Rise time first peak T1	0,5 μ s $\pm$ 30 %
Oscillation frequency 1/T	100kHz $\pm$ 10 %
Decaying of Pk1 to Pk2	40 % - 110 %
Decaying of Pk2 to Pk3	40 % - 80 %
Decaying of Pk3 to Pk4	40 % - 80 %
Decaying other peaks	no requirements for other peaks
Short circuit current 12 Ω	500 A $\pm$ 10 %
Short circuit current 30 Ω	200 A $\pm$ 10 %
Short circuit current 50 Ω	120 A $\pm$ 10 % option RWG / N7.1 module, no peak current measurement
Wave shape current	
Rise time first peak tr T1	< 1 μ s
Oscillation frequency 1/T	100 kHz $\pm$ 10 %
Decaying	no requirements
Polarity	positive / negative / alternating
Repetition rate	250 V – 4000 V max. 1 Hz (1s - 999s) > 4000 V max. 0.1 Hz (10s – 999s)
Events preselection	1 - 30'000 or endless
Counter	1 – 1'000'000

Trigger

Trigger of pulses	AUTO, MAN, EXTERN
Synchronization	0 - 360°
Resolution	1°

Output


Direct	HV-banana connector; Zi = 12 Ω / 30 Ω / (50 Ω ; option RWG/N7.1)
Coupling network	L-N, L-PE, N-PE, L+N-PE
DUT power mains supply	AC 300 V / 16 A / 50/60 Hz DC 300 V / 16 A

Measurements

CRO	5 V Trigger
CRO $\hat{U}$	10 Vp at 7.0 kV
CRO $\hat{I}$	Output signal is not suitable for Ringwave current measurement
Peak voltmeter	0 – 7000 V
Peak current meter	Displayed value only as trend suitable, accuracy > 20%

Test routines

Quick Start	Immediate start, all parameters adjustable during a running test
-------------	--



6.5. Telecom Surge Generator as per IEC 61000-4-5 (TSurge module)**UCS 500N5T (includes TSurge module) TSurge7 (external)****As per ITU and ETS recommendations**

Output voltage open circuit	160V – 5'000V $\pm 10\%$	250V – 7'000V $\pm 10\%$
Pulse 10/700 μ s		
Front time T_F (rise time t_r)	10 μ s $\pm 30\%$ (1.0 μ s $\pm 30\%$)	
Pulse duration t_d	700 μ s $\pm 20\%$	

As per FCC part 68 Pulse B

Output voltage open circuit	160V – 5'000V $\pm 10\%$	250V – 7'000V $\pm 10\%$
Front time T_F	9 μ s $\pm 30\%$	
Pulse duration t_d	720 μ s $\pm 20\%$	
Output current short circuit	4 – 100A	6 – 175A
Rise time t_r	5 μ s $\pm 30\%$	
Pulse duration t_d	320 μ s $\pm 20\%$	

As per IEC 61000-4-5

Pulse 10/700 μ s		
Open circuit output voltage	160V – 5'000V $\pm 10\%$	250V – 7'000V $\pm 10\%$
Rise time t_r	10 μ s $\pm 30\%$	
Pulse duration t_d	700 μ s $\pm 20\%$	
Short circuit output current	4 – 100A	6 – 175A
Rise time t_r	5 μ s $\pm 20\%$	
Pulse duration t_d	320 μ s $\pm 20\%$	

Coupling

As per ITU	For 2 wire T1 and T2 with 25 Ω each
As per FCC part 68	For 2 wire T1 and T2 with 25 Ω each
As per IEC 61000-4-5	For 4 wire T1,T2,T3,T4 with 100 Ω each
	External networks are required for other applications (options)

General

Energy storage capacitor	20 μ F
Polarity	Positive, negative or alternating
Counter select	1 – 30,000 or endless

Dimensions

Housing	19", 3HU, 450x500x155mm (ext. TSurge6.1 module)
Weight	approx. 11.85kg

Accessories Included

HV cable set	Connect the TSurge module to UCS 500N7
Control cable	To control TSurge via UCS 500N7
EUT adapter	socket depends on the country of use

6.6. EUT Supply Specifications

Standard models

Model	CDN		Remarks
UCS 500N5	300V	16A 1- ph	DC 300V / 16A
UCS 500N5.1	300V	32A 1- ph	DC 300V / 32A
UCS 500N7	300V	16A 1- ph	DC 300V / 16A ANSI
UCS 500N7.1	300V	32A 1- ph	DC 300V / 32A ANSI

DC current specification for all UCS500N model: I_{max.} = 16A dc (where not otherwise specified)



EUT Fuse

The UCS 500Nx models have **no internal fuse for the EUT** supply.
The user is responsible to adapt a suitable fuse for the EUT outside the UCS 500Nx

6.7. General Specifications

Mains supply	230V/115V, 50/60Hz
Power consumption	110W
Fuse	230V : 2 AT slow blow
	115V : 4 AT slow blow

Safety

Safety circuit	External interlock capability
Warning lamp	voltage free contact max. 250V 5A
Design	per IEC 1010, EN 61010

Interfaces

Serial	USB (compatible to USB 1.1 and 2.0)
Parallel IEEE	Address 1-31
Analog output	0-10V DC, to control an external power supply

	UCS 500N5	UCS500N7
Dimensions	19" / 3 HU	19" / 6 HE
Weight	app. 25 kg	ca.. 30 kg

6.8. Environmental conditions

Temperature	10 °C to 35 °C
Humidity	30 % to 70 %; non condensing
Atmospheric pressure	86 kPa (860 mbar) to 106 kPa (1 060 mbar)

=> Not relevant data for the standards can be changed by the manufacturer <=

6.9. Technical data of special generators

This chapter describes differing technical data from special generators

6.9.1. UCS 500N5.2T



Module

Built in modules
CDN

Surge, T-Surge
internal 1ph 16 A AC/DC

EUT:

Single Phase 300V 16 A

Dimensions and weight

Dimension
Weight
Housing

445 x 500 x 420 mm
Approx. 35 kg
6HU

6.9.2. UCS 500N5.5 and UCS 500N5.6 and UCS 500N5.9 for Railways application

Standards:

- EN 50121-3-2: 2015
- EN 50121-4: 2015
- EN 50121-5: 2015

Module : Burst
Surge

EUT

UCS 500N5.5: 300V 32A
UCS 500N5.6: 300V 32A
UCS 500N5.9: 300V 16A



Module

Built in modules

UCS 500N5.5: Burst, Surge
UCS 500N5.6: Burst, Surge, Power Fail
UCS 500N5.9: Burst, Surge, Power Fail

Surge Coupling
Surge impedance Ri

L - N, L - PE, N - PE, L + N - PE
2Ω, 10Ω, 40Ω Must be set manually by a bridge

REMARK : The complete Ri impedance is the addition of the 2Ω generator impedance und the manually set impedance (10Ω, 40Ω).

Coupling\ Ri	2Ω	12Ω	42Ω / 0.5 μF
L - N	ok	ok	ok
L - PE N - PE	⚠ no pulse	ok	ok
L + N - PE	⚠ no pulse	ok	ok

Dimensions and weight

Dimension 450 x 550 x 285 mm
Weight 34.2kg
Housing 6HU

6.9.3. UCS 500N5.11

Module : Burst
Surge
TSurge (optional)

EUT: 690V 16A



Module
Available Module Burst, Surge, TSurge
Surge coupling L - N, L - PE, N - PE, L + N - PEΩ

Dimensions and weight
Dimension 445 x 500 x 420 mm
Weight 37.6kg
Housing 9HU

6.9.4. UCS 500N6.5

Module : Surge
Ring

CDN External CNV503B7 6kV 32A

EUT: Three Phase
3x440V 32A

wave



Module
Built in modules Surge, Ringwave, TSurge

Coupling external CNV503B7 and TSurge

Dimensions and weight
Dimension 450 x 550 x 285 mm
Weight 26.0kg (UCS500N6.5) 38.0kg (CNV503B7) 12.1kg(TSurge)
Housing 6HU

6.9.5. UCS 500N6.7

Modules : Surge
Power Fail
Ringwave

EUT: Single Phase
Coupling Network 40A



Module
Built in modules Surge, Power Fail, Ringwave

Surge decoupling inductance 0.6mH internal dU at 40A 50Hz 230V approx. 15V

Dimensions and weight
Dimension 663 x 550 x 600mm
Weight 94 kg
Housing Minirack 12HU / rolls 50mm

6.9.6. UCS 500N7.1

Modules : EFT
Surge
Power Fail
T-Surge (option)

EUT: Single Phase 300V 32A

**Module**

Built in modules	EFT, Surge, Power Fail
Optional module	T-Surge
Remark	Ringwave not possible

Dimensions and weight

Dimension	445 x 500 x 420mm
Weight	approx. 37.6 kg
Housing	9HU

6.9.7. UCS 500N7.4

Modules : EFT
Surge
Power Fail
Ringwave

EUT: Single Phase 400V 16A

**Module**

Built in modules	EFT, Surge, Power Fail, Ringwave
Optional module	T-Surge
Remark	Ringwave not possible

Dimensions and weight

Dimension	445 x 500 x 420mm
Weight	42.8 kg
Housing	9HU

=> Not relevant data for the standards can be changed by the manufacturer <=

7. Maintenance setup and service

7.1. General

The generator is absolutely maintenance-free by using a solid state semiconductor switch to generate transients

7.2. Test set- up



When setting up the test national and international regulations regarding human safety have to be guaranteed.

It is recommended to connect the simulator to the ground reference plane of the test set-up.

The generators of the series 500, UCS, VCS, CSS, TSS and CNI, can be linked together to a fully automotive test set-up.

The set-up communicates via the IEEE / GPIB bus and is controlled by software. For setting up the system see the following figures:

Each generator can be operated individual as a single equipment.

7.3. Fuse for the EUT power supply

The EM Test pulse generators have no built in fuse for the EUT power supply. It is in the scope of responsibility of the user to protect the EUT external for the rated current.




The design of the external fuse must be match the following rules:

- fuse dimension must be **equal or smaller** than the **rated EUT current** of the connected **test generator**
- fuse must be designed for **protect the connected EUT** device under test in malfunction

Example of external fuse

Fuse in the building is designed for 32A. A Fuse box with 16A fuse protection is installed between the building supply and the test generator.

Test generator and EUT are now fused for 16A rated current



Example

16A protection with a 100A installation with a 3-phase fuse box.

The user has protected his Equipment Under Test with this additional fuse box for a rated current of 16A.



7.4. Insulating- or external transformer for EUT power supply



The recommended power of an external transformer must be **> 500VA**. The reason is the capacitive current of the internal filter capacitors inside the UCS 500N5 / N7.

7.5. Calibration and verification

7.5.1. Factory calibration

Every EM TEST generator is entirely checked and calibrated as per international standard regulations before delivery. A calibration certificate is issued and delivered along with a list of the equipment used for the calibration proving the traceability of the measuring equipment. All auxiliary equipment and accessories are checked to our internal manufacturer guidelines.

The calibration certificate and the certificate of compliance (if available) show the date of calibration.

The EM Test equipment are calibrated in the factory and marked with a calibration mark. The used measuring instruments are traceable to the Swiss Federal Office of Metrology.

The calibration date is marked. The validity of the calibration is to the responsibility of the user's quality system. Neither the certificate of calibration nor the corresponding label mark any due date for re-calibration.



Example: Calibration mark

7.5.2. Guideline to determine the calibration period of EM Test instrumentation

Our International Service Departments and our QA Manager are frequently asked about the calibration interval of EM TEST equipment.

EM TEST doesn't know each customer's Quality Assurance Policy nor do we know how often the equipment is used and what kind of tests are performed during the life cycle of a test equipment. Only the customer knows all the details and therefore the customer needs to specify the calibration interval for his test equipment.

In reply to all these questions we like to approach this issue as follows :

EM TEST make use of a solid state semiconductor switch technique to generate high voltage transients. A precious advantage of this technique is the absolute lack of periodical maintenance effort. In consequence thereof a useful calibration period has to be defined based on two criteria :

- The first one is the customer's Quality Assurance Policy. Any existent internal regulation has to be applied at highest priority. In the absence of such internal regulation the utilization rate of the test equipment has to be taken into consideration.
- Based on the experience and observation collected over the years **EM TEST recommend a calibration interval of 1 year** for frequently used equipment. A 2-years calibration interval is considered sufficient for rarely used test generators in order to assure proper performance and compliance to the standard specifications.

7.5.3. Calibration of Accessories made by passive components only:

Passive components do not change their technical specification during storage. Consequently the measured values and the plots stay valid throughout the storage time. The date of shipment shall be considered as the date of calibration.

7.5.4. Periodically In-house verification

Please refer to the corresponding standard before carrying out a calibration or verification. The standard describes the procedure, the tolerances and the necessary auxiliary means. Suitable calibration adapters are needed. To compare the verification results, EM Test suggests to refer to the waveshape and values of the original calibration certificate.

All calibrations and verifications are always done without mains supply voltage connected to the coupling network input.




Danger

Before starting the calibration or verification
remove the EUT Mains Supply
from the generator and from the coupling network

8. Delivery Groups

8.1. Basic equipment

- Generator type UCS 500N5 with recommended modules (Burst, Surge, Power Fail, TSurge)
UCS 500N7 with recommended modules (Burst, Surge, Power Fail, TSurge, Ringwave)
- Mains cable
- Mains cable for the EUT supply
- Cable black 0.5m 4mm Safety plug for phase synchronization (PF1-SYNC)
- K - USB cable USB A / B , 3m
- Adapter for power cable
- Manual (on memory stick)
- Calibration certificate



8.2. Accessories and options

- **ESA Adapter for adapt different power mains connectors**

As accessories adapters to different power mains connectors are part of the delivery of EM TEST surge generators. E.g. these are adaptors for Schuko - US - AUS - UK power mains connectors.

Most of these commercially available power mains sockets cannot withstand surge voltages higher than 4000V. Therefore each of these EM TEST adaptors are labeled to be **used up to 4000V** maximum.

In case that the EM TEST surge generator can generate higher surge voltages than 4000V a sparkover at the power mains socket may occur.


Customers shall be aware of this matter and shall **not use higher voltages than labeled** on the adapter.

For **testing higher voltages** it is necessary to use high voltage cables with sufficient isolation and safety banana connectors connected direct to the generator output plugs (L-N-PE).



Burst

- **CA EFT Kit** Calibration Adapter for Burst verification on EUT output + KW50 + KW1000
- **KW 50** Matching resistor 50 Ω with integrated attenuator (1:100)
- **KW 1000** Matching resistor 1000 Ω with integrated attenuator (1:500)
- **HFK** Capacitive coupling clamp as per IEC 61000-4-4 to couple the fast transients to signal and data lines.
- **CA HFK** Calibration kit for capacitive coupling clamp as per IEC 61000-4-4 Ed.3
 - Flexible plate insulated
 - Support for KW 50 and adapter to KW 50
- **CNE 503** external 3 phase coupling/decoupling network
 - EUT Mains 400 V rms max. // 480V for USA
 - Rated current $I_n = 16 \text{ A} / 32 \text{ A} / 63 \text{ A} / 100 \text{ A rms}$
 - Mains frequency 50/60 Hz
 - Coupling to all phases Lx, N, PE. Control with EFT 500.
- ITP Radiating set for immunity and emission
- **A6dB** as additional 6 dB / 50 Ω attenuator of the test signal
- **PUW 500** EUT monitoring



Surge

- Coupling/decoupling network as per IEC 61000-4-5 for signal lines type CNV 504/508 (4 wires and 8 wires)
- 3 phase CNV 503 up to 100A
- TSurge module



TSurge 7

Power Fail

- **V4780 transformer with taps**
 - Transformer with taps at 40%, 70%, 80%
 - 230V / 16A
- **MV 2616 Variac**
 - Motorvariac 0-260V / 16 or 32A
 - Control signal 0-10V dc.

**Magnetic field**

- **MS 100** Magnetic field antenna
- **MC 2630** Current transformer up to 30A/m
- **MC 26100** Current transformer up to 1000A/m



MC2630



MC26100

General for Burst and Surge

- **CNI 503 external coupling/decoupling network**
 - EUT mains supply 400 V rms max. // 480V for USA
 - Nominal current $I_n = 16 \text{ A} / 32 \text{ A} / 63 \text{ A} / 100 \text{ A rms}$
 - Frequency 50/60 Hz
 - Coupling to all lines, N, PE
 - 50Ω Burst output The coupling will be controlled by the UCS 500 or EFT 500
 - Output for Surge coupling to other coupling networks as CNV types ...
- **User software " iec.control "**
 - Test, analysis and documentation with windows
 - License version for testing according the most automotive standards
 - Report generator with export function to word-processing software

**USB Interface**

- **FER-USB**
Ferrite for suppress burst pulses on the USB cable.
Application: 8 turns for the best result. max. 10cm above ground.

The included USB cable has integrated ferrites and is suitable for burst tests with the UCS 500. Interferences usually occur on the computer side. With the ferrite-FER USB Interference will be attenuated additionally on the USB cable.



9. EFT Burst as per IEC 61000-4-4

Burst Module 5/50ns



If the user reduces the test voltage in **Quick Start** or in the **Manual Standard Test Routine**, the **storage capacitor will be discharged only by the burst pulses**. The result is a higher test voltage on the EUT than indicated on the display until the storage capacitor is discharged to the preselected value.

If the voltage reduction is several 100V the discharge time to the correct test voltage can be some seconds. The discharge time depends on the repetition rate t_r and the duration t_d of the burst pulse.

Pressing STOP / START will discharge the storage capacitor over the discharge resistor immediately. After the START the test will continue with the correct voltage level.

9.1. Operation

The Burst menu offers different test routines for burst testing.

Burst	IEC 61000-4-4
F1 : Quick Start	
F2 : Standard test routines	
F3 : User test routines	
F1	F2
F3	F4
F5	F6
F7	

F1 Quick Start

Easy and fast online-operation with the equipment.

F2 Standard test routines

The operator can select between various preprogrammed test routines as required in different standards

F3 User test routines

The operator can select between various preprogrammed test routines which helps to accelerate testing and which are very helpful especially during design.

9.1.1. Quick Start

Easy and very fast operation of all standard functions of the equipment. The latest simulator settings are stored automatically and will be recalled when Quick Start is next selected.

Burst		Quick start	
V	= 500V	f	= 5kHz
td	= 15ms	tr	= 300ms
cpl	= L	+/-	= +
T	= 01:00min		

START CHANGE

F1 F2 F3 F4 F5 F6 F7

Press **CHANGE** and the test parameters parameter can be changed.

Select the desired parameter with the related function key and change the value by turning the front panel knob.

The cursor allows the user to define the digit to be changed (fast or slow change).


Press **START** and the test starts immediately with the displayed test parameters.

The operator now can navigate with the **Cursor** from parameter to parameter. The blinking parameter can be changed by turning the front panel knob.

Burst specification as per IEC 61000-4-4 Ed2 : 2004

f = 5kHz
td = 15ms
tr = 300ms

f = 100kHz
td = 0.75ms
tr = 300ms



9.1.2. Standard test routines

The user can select preprogrammed standard test routines.

Page 2

Burst Standard test routines						
F1	:	IEC 61000-4-4	Level 1		500V	
F2	:	IEC 61000-4-4	Level 2		1000V	
F3	:	IEC 61000-4-4	Level 3		2000V	
F4	:	IEC 61000-4-4	Level 4		4000V	
F5	:	EN 61000-6-1	Generic		1000V	
F6	:	EN 61000-6-2	Generic		2000V	
F7	:	Manual test routine				
F1	F2	F3	F4	F5	F6	F7

Page 3 (Show parameters and start the test)

Burst	IEC 61000-4-4 Level 3					
V = 2000 V		f = 100 kHz				
cpl = COM						
START CHANGE						
F1	F2	F3	F4	F5	F6	F7

T	:	00:01 min	99:59 min			
f	:	5.0 kHz	100 kHz			
cpl	:	COM	/ ALL / CCC			
T	f	cpl				
1:00	100	COM				
F1	F2	F3	F4	F5	F6	F7

The function „**Change**“ enables the operator to switch between 5kHz/100kHz spike frequency. The burst duration will be automatically matched to 15ms respectively 0.75ms.

The coupling mode can be selected depending on the IEC 61000-4-4 edition version (ALL 1994 / COM 2004) Additionally the operator can enter the required test time.

Manual standard test routine

Burst	Standard routine IEC 61000-4-4					
<- ->	O					
Level 3	+ 2000V	L N		5.0 kHz		
				Test time 0:00:45 h		
START	+/-	L	N	PE	L N PE	f
F1	F2	F3	F4	F5	F6	F7

Within this test routine all standard parameters can be changed online during testing at the **1-phase and coaxial 50Ω output of the UCS 500N** generator. This procedure therefore is very easy and fast to use.

By pressing the function „f“ the operator can select between 5kHz and 100kHz spike frequency. The burst duration will be automatically matched to 15ms respectively 0.75ms.

Attention: The couplings are controlled manually. The user is responsible to test according the old or new standard IEC 61000-4-4.

Example:

- By pushing the cursor ←→ the test level will be increased/decreased to the next standard level.
- By turning the INC knob (o) the test level can be continuously adjusted.
- Pressing the function keys the related function will be immediately activated.
- The displayed time will be reset to zero after every new setting.

All functions can be operated during the running test.

9.1.3. User Test Routines

The user can program, save and recall his own specific test routines. The next pages shows the selection of the functions.

USER TEST ROUTINES

F1 : Synchronized
 F2 : Random burst release
 F3 : Voltage change after T by
 F4 : Frequency sweep in one single burst
 F5 : Frequency sweep with constant pulse numbers
 F6 : Frequency sweep with constant burst duration
 F7 : Change polarity +/- after T

F1 F2 F3 F4 F5 F6 F7


After selection the last used test parameters will be indicated on the display.

Customized test routines

The software controls user test routines according to the specification of the user. All limitations are the same as defined under Quick Start.


Synchronized with a fixed phase angle

The burst is triggered with respect to the phase angle of the power supply connected to the Sync input at the rear panel of the equipment. The power supply must be an AC voltage with a nominal frequency of 16 to 500Hz. The phase must be connected to L. This can be checked by the lamp connected to the L input.




Random burst release

No repetition rate is selected. The single burst will be triggered by statistics in the limits of 20 to 2000ms as time between two bursts. All limitations are the same as defined under Quick Start.



Voltage change after T by ΔV The test voltage is increased from V_1 to V_2 by steps of ΔV after the defined test time T. All limitations are the same as defined under Quick Start. The limitation of the max. generated number of spikes is related to the higher voltage of V_1 or V_2 .



Frequency sweep in one single burst


During one single burst the frequency sweeps from f_1 to f_2 .
For this function the following limitations have to be respected:

tr.	$\geq$	100 ms
f_1	$\leq$	f_2
td	$\geq$	5.0 ms
td	$\geq$	$5 / f_1$
tr. -td	$\geq$	50 ms

Note: The maximum value for frequency, burst duration td and voltage are in dependence of each other and therefore limited by the generator performance. The practical limits of the UCS500N7 are 20kHz for f_2 and 50ms for the burst duration td. The limits of the generator model UCS 500N5 are approx. 10 times higher.


Frequency sweep with a constant pulse numbers

The burst duration is increased from td_1 to td_2 by steps of Δ td after the defined test time T. All limitations are the same as defined under Quick Start. The limitation of the max. generated number of spikes is related to the higher duration of td_1 or td_2 .




Frequency sweep with a constant duration after T by Δf

The spike frequency is increased from f_1 to f_2 by steps of Δf after the defined test time T. All limitations are the same as defined under Quick Start. The limitation of the max. generated number of spikes is related to the higher frequency of f_1 or f_2 .



Polarity change after T

The polarity will be changed from + to - after the defined test time T.




9.2. Burst generation


Discharge switch:

The discharge switch is a highly reproducible semiconductor switch. Spike frequencies up to 1000kHz are by a factor of 10 higher than recommended in the actual EFT standards. This means of course that also the pulse energy would be 10 times higher. This is not generally possible for the high voltage switch. Therefore the following limitation protects the pulse forming circuit against overload:

Pulses / s



Pulses / burst



9.3. Test level with Burst as per IEC 61000-4-4 Ed.2.

Burst generators, which the specifications in accordance with IEC 61000-4-4 Ed2: 2004 fulfills, have a limitation of the maximum output voltage. The efficiency of the burst pulses decreases with the numbers of couplings.

Therefore the maximum test level is limited by the number of coupling on several lines.

Generators with the modification in accordance with IEC 61000-4-4 Ed2: 2004 the max. test levels have the following limits:

Coupling	UCS N5	UCS N7
50 Ω	5500V	5500V
1 coupling any	5500V	5500V
2 couplings any	5500V	5000V
3 couplings any	5500V	5000V

Generator with CNI 503 / CNE 503		
50 Ω	5500V	5500V
1 coupling any	5500V	5500V
2 couplings any	5000V	5000V
3 couplings any	5000V	5000V
4 couplings any	4500V	4500V
5 couplings any	4500V	4500V


9.4. Coupling/decoupling network

The decoupling part of the coupling network has to:

- filter the interference pulses in the direction to the power supply;
- protect other systems that are connected to the same power supply and
- realize a high impedance of the power supply, e.g. battery supply.

9.4.1. Coupling/decoupling network for ac/dc power lines

The coupling network couples the EFT pulses via 33 nF capacitors onto the AC or DC power lines. As coupling devices capacitors of sufficient strength and bandwidth shall be used according to IEC 61000-4-4.



The coupling on signal lines can usually not be effected capacitive without interfering with the signal flow. It is often impossible to contact the required circuit (direct), e. g. coaxial or shielded cables. In this case the coupling is realized with the capacitive coupling clamp. The interference simulator can be connected on both sides of the coupling clamp.

Coupling method:

Test duration: At least 2 minutes in positive and negative polarity. The test duration must be at least as long for examine all functions of the EUT

Coupling IEC 61000-4-4 edition 2 (2004) and later versions requires to couple all lines simultaneously in Common Mode coupling. This means that a EFT test needs two tests with 60s (positive and negative 60s each).

9.4.2

IEC 61000-4-4 (1995, 2001) requires all line combination to be tested individually.

A 1-phase EUT needs to test all combination L, N, PE, L+N, L+PE, N+PE, L+N+PE each with two tests with 60s (positive and negative 60s each). Total test time 14 x 60 seconds


9.4.2. Capacitive coupling clamp

- The coupling clamp is not matched by 50 ohm. If the clamp is matched there exists an additional magnetic coupling, which may cause completely different test results.
- The clamp should be placed in a distance of 0.5m to the equipment under test. When the distance is shorter distances, the EUT may be influenced by radiation.
- If the EUT includes two separate equipment, the test should be conducted on each single equipment with the required distance.



9.5. Burst Test Setup


- The test generator and the coupling network should be connected to the reference ground plane (acc. to high frequency requirements).
- The equipment under test must be isolated from the reference ground plane. The distance should be 10cm. Being part of the EUT, these requirements are also recommended for all connected cables. The EUT should only be grounded if this is recommended by the installation guideline. For safety reasons, the test without any ground connection should be conducted as well (at 100MHz 1m ground cable has an impedance of about 600 ohm)
- Whenever possible the test set-up and the cabling should always be the same; e.g. for testing power lines it would be possible to fix the cables on the test table for all tests in the same way.
- Lines under test and all other lines should be decoupled strictly.



9.5.1. Test setup with capacitive coupling clamp

When using the coupling clamp, the minimum distance between the coupling plates and all other conductive surfaces (including the generator), except the ground reference plane beneath the coupling clamp and beneath the EUT, shall be at least 0,5 m.

The distance between any coupling devices and the EUT shall be $(0,5 - 0/+0,1)$ m for tabletop equipment testing, and $(1,0 \pm 0,1)$ m for floor standing equipment, unless otherwise specified in product standards. When it is not physically possible to apply the distances mentioned above, other distances can be used and shall be recorded in the test report.



10. Surge Immunity as per IEC 61000-4-5

Surge Module 1.2/50 μ s – 8/20 μ s



WARNING

The internal coupling network is designed for **mains frequency 50Hz / 60Hz**.

When L – N coupling is selected an **additional current of approx. 1.5A** flows, caused by the 18 μ F coupling capacitor and the pulse forming network. A similar current appears during the couplings to PE.

Tests with 400 Hz mains frequency **destroy the coupling network**. An external coupling network is recommended with inductors and capacitors matched to the 400Hz mains frequency.

10.1. Operation

The Surge menu offers different test routines for burst testing.

Surge	IEC 61000-4-5/9
F1 : Quick Start	
F2 : Standard Test Routines	
F3 : User Test Routines	
F4 : Pulse Magnetic Field	
F7 : Setup Current limiter	
F1	F2
F3	F4
F5	F6
F7	

F1 Quick Start

Easy and fast online-operation of the equipment.

F2 Standard test routines

The operator can select between various preprogrammed test routines. By pressing the related function key the test will be started automatically with the specified test parameters.

F3 User test routines

The operator can select between various preprogrammed test routines which helps to accelerate testing and which are very helpful especially during design.

F4 Pulse Magnetic Field

Within this menu the pulse magnetic field test as per IEC 61000-4-9 is supported.


F7 Set-up Current limiter

Within this menu the operator can select the maximum allowable surge current for the EUT. The limiter can be selected for both coupling modes, common mode (line to ground) and differential mode (line to line).

10.1.1. Quick Start

Easy and very fast operation of all standard functions of the equipment. The latest simulator settings are stored automatically and will be recalled when Quick Start is next selected.

Surge		Quickstart	
V	= 2000V	A	= 0 dgr
+/-	= +	cpl	= L + N - PE
tr	= 10s	tri	= Auto
n	= endl		
START CHANGE			
F1	F2	F3	F4
F5	F6	F7	



Press **CHANGE** and the test parameters parameter can be changed.

Select the desired parameter with the related function key and change the value by turning the front panel knob. The cursor allows the user to define the digit to be changed (fast or slow change).

At polarity setting ALT it is necessary to double the number of impulses. Example $n=2 \Rightarrow$ one impulse positive and one impulse negative.

Pressing the ESC button will bring the user back to the previous level from where the test can be restarted with new levels.

Press **START** and the test starts immediately with the displayed test parameters.

All functions keys except F2 (if MAN TRIGGER is selected) can stop the test routine. The latest setting will be displayed.

Any pressing of a function key will indicate the functions START, CHANGE or CONTINUE. F3 will continue the same test routine. If the user selects at first START or CHANGE the test will be stopped completely

Press **ESC** will bring the user back to the previous menu level.

Page 3 (Start)

Surge		Quickstart	
V	= 2000V	A=	0 dgr
+/-	= +	cpl	= L + N - PE
Rep	= 10 s	tri	= Auto
n	= endl.		
Vsoll	= 2000V	U	= + 2000V
STOP		I	= + 0000A
		COUNTER	0000043
F1	F2	F3	F4
F5	F6	F7	

While a test is running the user can select parameters with the cursors $\leftarrow \rightarrow$. The selected parameter then can be changed online with the inc/dec knob.

10.1.2. Standard test Routine

Page 2

Standard test routines

F1 : IEC 61000-4-5	Level 1	500V
F2 : IEC 61000-4-5	Level 2	1000V
F3 : IEC 61000-4-5	Level 3	2000V
F4 : IEC 61000-4-5	Level 4	4000V
F5 : EN 61000-6-1	Generic	2000V
F6 : EN 61000-6-2	Generic	2000V
F7 : Manual test routine		

F1 F2 F3 F4 F5 F6 F7

With the selection of F1F6 the test is conducted automatically with the parameters and the test sequence as required per IEC 61000-4-5. The only parameters the operator is able to change are the repetition rate and the number of pulses per test level. With a faster repetition rate as required in the standard the total testing time can be reduced significantly.

Tests with the function keys F1...F4 use the given testlevel with all couplings (common- and differential mode).

Iteration of the standard test procedure as per IEC 61000-4-5

The surges have to be applied synchronized to the voltage phase at the respective angle and the peak value of the a.c. voltage wave (positive and negative).

The surges have to be applied line to line and line(s) and earth. When testing line to earth the test voltage has to be applied successively between each of the lines and earth.


The test voltage has to be increased by steps from the lowest test level up to the test level specified in the product standard or test plan.

Phase angle : 0°, 90°, 180°, 270°

Polarity : negative , positive

Coupling : L - N , L - PE , N - PE

Voltage : 500V, 1000V, 2000V, 4000V



List of settings EN 61000-6-1 (each setting with 5 pulses)

Setting	Voltage	Coupling	Polarity	Phase angle
1	500	L-N	pos	0
2				90
3				180
4				270
5			neg	0
6				90
7				180
8				270
9		L-PE	pos	0
10				90
11				180
12				270
13			neg	0
14				90
15				180
16				270
17		N-PE	pos	0
18				90
19				180
20				270
21			neg	0
22				90
23				180
24				270
25	1000	L-N	pos	0
26				90
27				180
28				270
29			neg	0
30				90
31				180
32				270

Setting	Voltage	Coupling	Polarity	Phase angle
33	1000	L-PE	pos	0
34				90
35				180
36				270
37			neg	0
38				90
39				180
40				270
41		N-PE	pos	0
42				90
43				180
44				270
45			neg	0
46				90
47				180
48				270
49	2000	L-PE	pos	0
50				90
51				180
52				270
53			neg	0
54				90
55				180
56				270
57		N-PE	pos	0
58				90
59				180
60				270
61			neg	0
62				90
63				180
64				270

Standard Test Routines

Page 3 (show parameters)

Surge	Generic EN 61000-4-5					
		5s				AUTO
		10 Pulse				
+ 1000V						
L-PE	90grd					Counter
		U=970V				000002
STOP	STEP	I = 010A				000034
F1	F2	F3	F4	F5	F6	F7

- The counter shows the number of triggered pulses per actual test level as well as the number of all triggered test pulses within the running test sequence.
- Pushing the function key F2 STEP will bring you into the next iteration sequence.

Manual test routine

Surge	Standard		IEC 61000-4-5			
<- ->	O			O		
Level3	+2000V	10s		0 grd		L-N
START	+/-	O V/A	Rep	L-N	L-PE	N-PE
F1	F2	F3	F4	F5	F6	F7

Within this test routine all standard parameters can be changed online during testing. This procedure therefore is very easy and fast to use.

Example:

- Operating the cursor will increase/decrease the test level to the next level required in the standards
 - By turning the inc knob the test voltage V resp. the phase angle A will be adjusted continuously. The blinking circle shows which parameter can be changed. Pressing the function „O V/A“ will change between both parameters.
 - Pressing the function keys will activate immediately the related function.
- All functions can be changed during the running test.

10.1.3. User Test Routines

The user can program, save and recall his own specific test routines. The next pages shows the selection of the functions.

User Test Routines

F1 : Change polarity after n pulses
 F2 : Voltage change after n pulses by ΔV
 F3 : Change the phase angle after n pulses by Δa
 F4 : IEC coupling after n pulses
 F5 : ANSI A coupling after n pulses
 F6 : ANSI B coupling after n pulses

USC 500N7 Firmware 9.00 and iec.control V 5.2.3.0 or later
 USC 500N7 Firmware 9.00 and iec.control V 5.2.3.0 or later

F1 F2 F3 F4 F5 F6 F7


After selection the last used test parameters will be indicated on the display.

Customized test routines

The software controls user test routines according to the specification of the user. All limitations are the same as defined under Quick Start.


F1 Change polarity after n pulses

After the release of the preselected number of pulses the polarity is changed. The procedure always starts with positive polarity and changes than to negative. The same parameters as under Quick Start can be selected.




F2 Change test level V after n pulses by ΔV

The test voltage V is changed from V1 to V2. After the preselected number pulses the test level is changed by ΔV until V2 is reached. The same parameters as under Quick Start are selectable. For the limitation of the max. admissible repetition rate the higher value of V1 and V2 is valid.




F3 Change the phase angle A after n pulses by ΔA

The phase angle related to which the surge pulse is released is changed from A1 to A2. After the preselected number of n pulses the actual phase angle is changed by ΔA until A2 is reached. The same parameters as under Quick Start can be selected.




F4 IEC coupling after n pulses


The coupling mode will automatically be changed after the preselected number of pulses has been released. All possible coupling modes will be selected. . The same parameters as under Quick Start can be selected.

**F5 ANSI A coupling after n pulses**

The coupling mode with 12Ω and 9μF will automatically be changed after the preselected number of pulses has been released. All possible coupling modes will be selected. . The same parameters as under Quick Start can be selected.

**F6 ANSI B coupling after n pulses**

The coupling mode with 2Ω and 18μF will automatically be changed after the preselected number of pulses has been released. All possible coupling modes will be selected. . The same parameters as under Quick Start can be selected.

**Surge Generator and coupling impedances**

	Line to Line	Line to PE (IEC) Line to GND (ANSI)
IEC	2Ω; 18μF	12Ω; 9μF
ANSI A	12Ω; 9μF	12Ω; 9μF
ANSI B	2Ω; 18μF	2Ω; 18μF


10.1.4. Phase synchronization in 3-phase system

Device	Firmware versions	
UCS 500N5	From V 4.41 to V 4.99 and	from V 5.00 and higher
UCS 500N7	From V 7.43 to V 7.99 and	from V 8.03 and higher

The built in hardware phase synchronization is between the sync input and PE.
The user must connect the synchronize line L1 with the sync plug.

The synchronization is based on a 3-phase system where neutral is connected to PE in the supply system.

As Standard **line L1 is connected to the sync plug**. For coupling other lines, the UCS500 hardware will automatically shift the phase angle in relation to the used coupling.



The tables below shows the correction angels considering the phase in a 3-phase system with connected L1 to the sync input. The UCS500 firmware will automatically add the correction angle to the settled value.

Synchronization: L1 to Sync input

	Sync. Source	Correction angel added by the UCS 500 firmware					
Coupling	L1-PE	L1-N	L2-N	L3-N	L1-L2	L1-L3	L2-L3
Sync.-Angel	0°	0°	120°	240°	330°	30°	90°
	90°	0°	210°	300°	60°	120°	180°
	180°	0°	300°	30°	150°	210°	270°
	270°	0°	30°	150°	240°	300°	0°


The correct phase angle will be set automatically from the UCS 500N.

Device	Firmware versions
UCS 500N5	Up to V 4.40
UCS 500N7	Up to V 7.42 and from V 8.00 to V 8.02

The built in hardware phase synchronization is between the sync input and PE.
The user must connect the synchronize line with the sync plug.

The synchronization is based on a 3-phase system where neutral is connected to PE.

As Standard **line L1 is connected to the sync plug.**



The table below shows the correction angels considering the phase in a 3-phase system.

Synchronization: L1 to Sync input

	Sync. Source	Settled phase angel value for coupling:					
Coupling	L1-PE	L1-N L1-PE	L2-N L2-PE	L3-N L3-PE	L1-L2	L1-L3	L2-L3
Sync.- Angel	0°	0°	0°	0°	330°	30°	90°
	90°	90°	90°	90°	60°	120°	180°
	180°	180°	180°	180°	150°	210°	270°
	270°	270°	270°	270°	240°	300°	0°

Example: For setting the coupling L1-L2 with a 180° phase angle **set the generator phase to 150°**

10.1.5. Pulsed magnetic field as per IEC 61000-4-9

Page 2 (Select function)

Surge Magnetic field	IEC 61000-4-9
F1 : Quick Start	
F2 : Magnetic field as per IEC 61000-4-9	
F7 : Setup magnetic field	

F1 F2 F3 F4 F5 F6 F7

The operation of the pulse magnetic field test is similar as to the standard surge routines.

Page 2 (show parameter)

QUICKSTART	
H = 300A/m	A = 0 dgr
+/- = +	cpl = "/" or "L-N"
tr = 10s	tri = Auto
n = 10	
START CHANGE	


F1 F2 F3 F4 F5 F6 F7

Press **START** and the test routines begin to work.


Press **CHANGE** and the actual parameters can be changed.

For magnetic field testing the antenna correction factor shall be included. The operator can enter this factor within the setup menu under the service routine.

Setup pulsed magnetic Test field



According IEC 61000-4-8 Ed 2, an additional 18 uF capacitor included in the IMN2 must be connected between the Generator (HV – COM on rear side) and the antenna.



Warning

Disconnect all power cables on the rear side at the Test supply plugs.

PF1, PF2 and N

Don't touch the antenna during the test!

10.1.6. Setup current limiter for surge current

The current limiter stops the test run when during a test the measured peak current of a surge pulse is higher than the preselected current value. This safety function protect the EUT for further surge pulses can occur any dangerous situation.

Depends of the different impedance of the surge generator, one current limiter for each impedance (2Ω , 12Ω) is available.

Page 2 (show parameter)

SETUP Current limiter						
F1 : I - Limiter	Differential mode	I_D				
F2 : I - Limiter	Common Mode	I_C				
I_D	I_C					
500A	54A					
F1	F2	F3	F4	F5	F6	F7

I_D = Current limiter Differential mode (line to line):

The generator impedance is 2Ω

I_C = Current limiter Common mode (line to ground):

The generator impedance is 12Ω



REMARK

The current limits in Software and Manual operation are two individual settings.

Software uses the **software settings** for I_D and I_C

Manual operating uses the **device settings** for I_D and I_C

Note :

Surge pulses with the coupling position “\” (potential free output at the rear side of the generator) use the settings of common mode. This is general used for the coupling network CNV 504 / 508 with 42Ω impedance. Using a coupling network CNI 503 or CNV 503, UCS uses the limits of differential and common mode.


10.1.7. Charging time for surge

The energy for charging the surge generator depends on the charging voltage of the internal capacitor of 11 μ F therefore the following minimum charging time is requested:

UCS 500N5 minimal charging time f(voltage setting)



UCS 500N7 minimal charging time f(voltage setting)



10.2. Surge pulse generation

Discharge switch:

The discharge switch is a highly reproducible semiconductor switch.


10.3. Coupling/decoupling network

The coupling network has to couple the interference pulses to the lines of a power supply system (AC or DC). Capacitive coupling is the specified coupling mode for surge testing.

10.3.1. Coupling to ac/dc power supply lines

The surge generator UCS 500 has an integrated coupling network in accordance with IEC 61000-4-5. It must be possible to test with different coupling modes:

Line	→	GND or	(source impedance is 12Ω)
Neutral	→	GND or	(source impedance is 12Ω)
L + N	→	GND or	(source impedance is 12Ω)
Line	→	Neutral	(source impedance is 2Ω)



The release of the surge pulses is mostly related to a certain phase angle.
The surge pulses are synchronized to the input signal at the rear Sync-connector.

Attention: The decoupling part of the coupling/decoupling network includes some capacitors for filtering of $20\mu\text{F}$ related to protective earth (chassis of the generator). This is to conform with the requirement of IEC 61000-4-5 concerning attenuation of the surge transients in direction to the power mains supply input of the CDN.

As consequence there will exist an increased current to PE (protective earth) which might be hazardous to the operator in case of a failure or wrong installation. Therefore it is very important to take the following points into account before setting the generator into full operation.:

1. Due to this increased current into the PE system no earth fault current protectors can be used within a surge testing area.
2. As consequence the surge generator shall be connected always to Protective Earth, even if no test is conducted.
 - via plugged in power mains supply cable including the PE wire!!!!!!
 - via plugged in EUT power mains supply at the rear side of the generator, including the PE wire !!!!
 - via Ground Reference Connector, screwed to the chassis of the generator.


These measures result in double safety in case of a fault

10.3.2. Coupling to I / O lines

The coupling to I/O lines is generally realized with other coupling networks than for power supply lines. The loading of the I/O lines with big coupling capacitors is mostly not possible. The data transmission may be disturbed.

For coupling to I/O lines special couplers as per IEC 61000-4-5 are available, such as the CNV 504N- and the CNV 508N-series for four respectively for eight wire systems.

For many application a special coupling network is required.



Danger

Using coupling networks CNV series
**Switch OFF the high voltage during
 manual change of the coupling**

10.4. Test set-up

According to the specifications of IEC 61000-4-5, the surge generator has a source impedance of 12ohm when the simulator is coupled between the lines and protective earth.

This will activate fault current detectors or protectors which may be installed in the laboratory.

Therefore it is important

- not to disconnect the surge simulator from protective earth (power cable)
- to have an installation where the simulator is connected via its ground reference connector to earth


11. Voltage Dips as per IEC 61000-4-11

Dips Module for voltage Dips and short interruptions.

11.1. Test setup for DIPS and Interruption tests

Voltage DIPS


For voltage DIPS a connection must be made from the PF2 UCS input to the motorvariatic PF2 or V4780, where the reduced voltage is present.



Interruption tests

For Interrupts connect the PF2 UCS input to the neutral as follows:

- **Motorvariatic** : PF2 output (default setting) set motorvariatic to zero volt.
- **V 4780** : Connect the cable to the N output at the V 4780



11.2. Operation

The Surge menu offers different test routines for burst testing. The bottom line shows the selected nominal voltage (Change in the menu F3 Setup / F6 Set voltage...)

Power Fail	IEC 61000-4-11 / 8 / 29
F1 : Quick Start	
F2 : Standard test routines	
F3 : User test routines	
F4 : Magnetic field	
Motorvariatic Mains Voltage 115V	

Display Firmware V9.04ax and higher

F1 F2 F3 F4 F5 F6 F7

F1 Quick Start

Easy and fast online-operation of the equipment.

F2 Standard test routines

The operator can select between various preprogrammed test routines as required in different standards. With the function key F4 the operator can select the standard routine for 50/60Hz magnetic field testing as per IEC 61000-4-8.

F3 User test routines

The operator can select between various preprogrammed test routines which helps to accelerate testing and which are very helpful especially during design.


F4 Magnetic Field

The operator can perform 50 / 60 Hz magnetic field test as per IEC / EN 61000-4-8.

11.2.1. Quick Start

Easy and very fast operation of all standard functions of the equipment. The latest simulator settings are stored automatically and will be recalled when Quick Start is next selected.

Power Fail			Quickstart		
A	=	0dgr	td	=	10.00ms
rep	=	0.50s	CH	=	ΔU
V2	=	250V	tri	=	Auto
n	=	endl.			
START CHANGE					



F1 F2 F3 F4 F5 F6 F7

Press **START** and the test routines begin to work.

Press **CHANGE** and the actual parameters can be changed.

All function keys except F2 (manual trigger) can **Stop** the test routine.

Explanations	
A	Phase angle
td	Duration of a single event
Rep	Repetition rate (time between two events)
CH	Channel select (PF1, PF2 or ΔU)
V2	Variable test voltage (controlled by 0-10 V analog voltage)
n	Number of events
tri	Trigger mode

Page 3 (Start)

Power Fail			Quickstart		
A	=	0dgr	td	=	10.00ms
rep	=	0.50s	CH	=	ΔU
U2	=	250V	n	=	endl.
tri	=	Auto			
			V =	230 V	Counter
STOP			I =	0.5 A	002317

F1 F2 F3 F4 F5 F6 F7

After "**START**" the display indicates the voltage and current at the TEST SUPPLY output. The measured voltage is ($V_{\text{peak}} / \sqrt{2}$) if there is a ac-signal on the sync input, otherwise V_{peak} . The voltage dips will be repeated with the preselected repetition rate and the counter will be increased.

When the operator is using faster repetition rates the indicated voltage level is not stable. A correct value can not be displayed.

All function keys, except F2 Manual **Trigger**, can stop the running test. After Stop the last setting is displayed for about 2 seconds. Then the functions **START**, **CHANGE** or **CONT** are indicated. F3 will continue the test.

During the QUICK START procedure the value for the angle is blinking. The blinking value always and at any time can be changed by turning the knob (inc/dec). With the cursor the actual blinking function can be changed.

Page 4 (Change)

Page 4 (Change)						
Power Fail				Quickstart		
A : 0dgr - 360dgr / async.						
A	td	rep	CH	U2	tri	n
0	10.00	050	ΔU	250	Auto	endl.

F1 F2 F3 F4 F5 F6 F7

The parameter to change can be selected by pressing a function key. The corresponding range will then be displayed.

11.2.2. Standard Test Routines

Standard test routines						
F1 : IEC 61000-4-11 (ac power supply mains)						
F2 : IEC 61000-4-29 (dc power supply systems)						
F3 : EN 61000-6-1 Generic standard						
F4 : EN 61000-6-2 Generic standard						
F7 : Manual test routine						
F1	F2	F3	F4	F5	F6	F7

11.2.2.1. F1: IEC 61000-4-11 (AC power supply mains)

Page 3

Power Fail		IEC 61000-4-11				
F1:	Level 1	0%	10.0 ms			
F2:	Level 2	0%	20.0 ms			
F3:	Level 3	40%	200 ms			
F4:	Level 4	70%	500 ms			
F5:	Level 5	80%	5000 ms			
F6:	Short Interruptions					
F7:	Voltage Variation					
F1	F2	F3	F4	F5	F6	F7


As long as the external variac MV2616 is used, controlled by an analogue 0-10V control voltage, the test is conducted automatically. If this option is not available the manual test routine shall be used.

Using a tapped transformer V 4780, the user must connect the PF2 UCS input with the correct plug at the V4780. At 0% selection the PF2 input must be connected to the neutral (0V) plug.

F1 ... F5: DIPS Level 1 to Level 5

Page 4 (Show parameter)


Power Fail		IEC 61000-4-11			Level 3	
V2%	=	40%	A	=	0 dgr	
td	=	200ms	tr	=	10s	
			n	=	3.	
					Counter	
START / STOP					000002	
F1	F2	F3	F4	F5	F6	F7



F6: Short interruptions

Page 4 (Show parameter)

Power Fail IEC 61000-4-11				Interruption		
V2% = 0 %				A = 0 dgr		
td = 5000ms				tr = 10s		
				n = 3		
						Counter
START / STOP						000002
F1	F2	F3	F4	F5	F6	F7




F7: Voltage Variation

Page 4 (Show parameter)

Power Fail	IEC 61000-4-11	Variation	
V2% =	70%	A =	0 dgr
ts =	20ms	tr =	10s
ti =	0.5s	n =	3
START / STOP			Counter 000002

F1 F2 F3 F4 F5 F6 F7



Attention: This is the Voltage Variation function which is required in the IEC 61000-4-11:2004. The Voltage Variation function which is conform with the previous IEC 61000-4-11 version is available in the USER TEST ROUTINES.

Attention: This is a the voltage variation function which is required in the IEC 61000-4-11: (2004-03) and simulate a voltage dip during a motor start. For this test requires for the ramp function a motorized variac MV 2616 is mandatory.

The parameters, defined in the standard are fix. The user can modify the bold marked parameters :

- Phase angle **W** [0 ... 360 dgr / asynchron]
- Repetition time **tr** [5s ... 999s]
- Number of Events **n** [1 ... 30'000 / endless]

The Voltage Variation function which is conform with the older IEC 61000-4-11:1995 is available in the menu **User test routines**.

11.2.2.2. F1: IEC 61000-4-29 (DC power supply mains)**Page 3**


Power Fail	IEC 61000-4-29		
F1:	Level 1	40%	10.0 ms
F2:	Level 2	40%	30.0 ms
F3:	Level 3	40%	100 ms
F4:	Level 4	40%	300 ms
F5:	Level 5	40%	1000 ms

F1 F2 F3 F4 F5 F6 F7

F1 ... F5: DIPS Level 1 to Level 5**Page 4 (Show parameter)**

Power Fail	IEC 61000-4-11		Level 3
V2% =	40%	Ch =	ΔU
td =	100ms	tr =	10s
		n =	3.
START / STOP			Counter 000002

F1 F2 F3 F4 F5 F6 F7



As long as the external dc supply is used, controlled by an analogue 0-10V control voltage, the test is conducted automatically. If this option is not available the manual test routine shall be used.

11.2.2.3. F3 / F4: EN 61000-6-1 / -2 (Generic)**F3...F4: Generic Test Routines****Page 3**

Power Fail	EN 61000-6-2		Generic
V2	td	A	n
70%	10.0 ms	0 / 180	3
40%	100 ms	0 / 180	3
40%	1000 ms	0 / 180	3
0%	5000 ms	0 / 180	3
START CHANGE			


F1 F2 F3 F4 F5 F6 F7

This test proceeds automatically with a blinking status of the actual sequence in the display. As long as the external variac MV2616 is used, controlled by an analogue 0-10V control voltage, the test is conducted automatically. If this option is not available the manual test routine shall be used.

Change parameters**Page 4 (Show parameter)**

Power Fail	EN 61000-6-2		Generic
tr :	0.01 s	-	99s
tr	10		

F1 F2 F3 F4 F5 F6 F7




11.2.2.4. F7: Manual test routine

In this menu the user can easy change the parameter online during the test.

Page 4 (Show parameter)

Power Fail	standard routine	IEC 61000-4-11			
<- ->	O			O	
Level 4	70%	500Ns		0 grd	
START	oV2/td		A		

F1 F2 F3 F4 F5 F6 F7

**Example:**

- Selecting the 70% level requires a 70% Vn power supply voltage at the input of PF2 at the rear panel of the UCS. Use for that the variac MV2616 (automatic), the matching transformer V4780 or your own power mains source available in your laboratory.
- By pushing the function keys will immediately activate the function
 - F1 : Start
 - F3 : oV2/td Exchange the knob function V2Level [%] / Dip duration
 - F6 : W Angle 0°, 180°, asynchronous
- By turning the inc knob the duration of a single event can be adjusted.

11.2.3. User Test Routines


Page 2 (Selection)

Power Fail User test routines
 F1 : Voltage variation as per IEC 61000-4-11
 F2 : Change angle after n events by ΔA
 F3 : Change duration after n events by Δt_d
 F4 : Inverse mode

F1 F2 F3 F4 F5 F6 F7

F1 Voltage variation as per IEC 61000-4-11

An external power source or motor driven variac is controlled by a 0-10V control signal. The operator can select the time per voltage level, the ramp up and ramp down of the voltage change and the voltage levels itself.



Page 2 (show parameters)

Power Fail		Voltage Variation	
V1	= 220 V	T1	= 10 s
V2	= 120 V	T2	= 1 s
V3	= 220 V	T3	= 10 s
Tf	= 2.0 s	Tr	= 2.0 s
tri	= AUTO	n	= 00010


START CHANGE

F1 F2 F3 F4 F5 F6 F7

Press **START** and the test routines begin to work.
 Press **CHANGE** and the actual parameter can be changed.


F2 Change angle after n events by ΔA

After n events the phase angle related to which the events are released will change from A1 to A2 by steps of ΔA until A2 is reached. The same parameters as under Quick Start can be selected.




F3 Change duration after n by Δt_d

After n events the duration of a single event will change from t_{d1} to t_{d2} by steps of Δt_d until t_{d2} is reached. The same parameters as under Quick Start can be selected.



F4 Inverse mode

The inverse mode can simulate a phase control circuit, switching power (voltage) on/off at a certain phase angle. The phase angle is selectable in the range of 0-180°. The voltage will be switched on/off in each half-wave. Inverse is only working in ΔU mode.



11.3. The Power Fail Test


The power fail simulator operates in the following mode:

PF1: The voltage supply at channel PF1 will be interrupted for the preselected time T1.

PF2: The voltage supply at channel PF2 will be interrupted for the preselected time T1.

ΔU : Channels PF1 and PF2 are supplied with different voltages; e.g. channel PF1 with nominal voltage, channel PF2 with 15% under-voltage.

- channel PF1 is switched off for the preselected time T1.
- channel PF2 is switched on for T1.




LED

Two LED's mounted on the front panel show if a channels is active or not. The LED of an active channel is lighted. During mode ΔU the LED display switches from one channel to the other.



Voltage interference

In order to accelerate the test procedure the voltage interference may be generated repetitively. In the operating mode „AUTO“ the events are released at a preselected interval time.



Power switches

The power unit of the simulator consists of two electronic power switches S1 and S2. The two separated input channels PF1 and PF2 are connected to each other at the front panel of the simulator via S1 and S2.

Input channels

The input channels PF1 and PF2 are located at the rear part of the equipment. Attention has to be given to the following:

1. The phase shall be connected correctly. When putting into operation check the lines with a phase tester or with the incorporated LED phase.
2. Phase must be set on L, neutral must be set on N.
3. This applies to both channels. If during installation phase and neutral is changed, the operator will cause a short-circuit at the input plug of the channel.
4. The neutral of both channels is connected internally and directly leads to the output.
5. The power switches can bear no more than a voltage of 350Veff.
6. If isolating transformers are used special care shall be taken to have both channels in phase. Otherwise too high voltages, in difference mode, may occur and destroy the internal protection devices (varistors).


11.4. Overcurrent

Power switches

The power switches are electronically protected against overload and short-circuits. The nominal current of the switches is 25A.

Special protection requirements of the EUT must be separately assured by the user.

Inrush currents of $\leq 500A$ are permitted. To avoid higher inrush currents of the EUT an electronic control limiting the inrush current is incorporated in the device.



Correct phase relation between PF1 and PF2

Over-voltage generated by connecting or disconnecting additional loads will be limited internally by varistors in parallel to the electronic switch.

Power Fail		Quickstart	
W	= 0dgr	td	= 10.00ms
Rep	= 0.50s	CH	= ΔU
U2	= 250V	n	= endl.
Tri	= Auto		
Overcurrent REMOVE SHORT CIRCUIT ! ON			

Example overcurrent message in display

F1 F2 F3 F4 F5 F6 F7

Occurs an overcurrent during a test, The PF switches will switch off immediately and the display shows:



This error message appears after a short circuit at the EUT output plugs. This current can be up to 700A during few μs and will be detect from the overcurrent detection.

For overcurrent handling proceed as follow:

1. **Disconnect the short circuit** and make sure to remove the failure.
2. Press **F7 ON**. This will switch on the PF switch again and returns the power to the EUT output.
3. Continue in the start menu with **CHANGE**, **START** or **CONTINUE**.

11.5. The Power Fail Test

The generator type UCS 500N5/N7 simulates the following interference :

- Voltage dips
- Voltage interruptions
- Voltage variations
- Inverse

11.5.1. Voltage Interruptions


Depending on the preselected test parameters at the front panel of the simulator the power supply for the EUT is interrupted for a certain time and at a certain phase angle (AC power supplies).

The power supply for the EUT is connected at the rear part of the simulator to channel PF1.

The power supply may be taken directly from the mains power supply or from a separate voltage source. Mostly used for this tests are motor driven variacs

Power fail tests are normally carried out at a nominal voltage and at maximum tolerance under-voltage.


The nominal voltage may be connected to PF1 and the reduced dip voltage to PF2.



The power fail test may be carried out in various operating modes:


High impedance interruptions

With ΔU mode the EUT supply is interrupted by the electronic switch. The PF2 input is not connected. The EUT must discharge itself internally.



Low impedance interruptions

The EUT supply is connected to PF1. The channel PF2 is short-circuited (L-N). The EUT supply is disconnected by the electronic switch of PF1 and the EUT will be discharged into a low impedance via the electronic switch of PF2



11.5.2. Voltage dips, voltage variations


Depending on the preselected test parameters, the test voltage is changed to a higher or to a lower value for a certain duration and at a certain phase angle.

Voltage variations are normally related to the nominal value of the supply voltage. Therefore two different variacs shall be connected at the rear side of the simulator.

- PF1 → Nominal voltage
- PF2 → Under- / overvoltage

The operation mode ΔU shall be preselected. The voltage variation is realized by switching the power supply from channel PF1 to channel PF2.

If a motor driven variac is available, it is also possible to drive the source by an analogue voltage 0 - 10V. This control voltage is available at the coaxial output at the rear part of the simulator



The control voltage is to be set via the operator menu or the interfaces of the PFS. A complete user software to drive ramps and functions is also available

11.6. DC Power networks

Basically there is no difference in the operation of the equipment between AC and DC power supplies. The only point the user should take care of are the grounding conditions.

The voltmeter, the "MONITOR" output and the LED are related to protective earth or to the simulator's chassis, respectively. Therefore these instruments can be used to check line or neutral and to measure at the output CRO U while the test procedure is running.

It results for the DC power supply operation:

- If it is possible to ground the "MINUS" pole of the DC supply, from the EUT point of view, the blue output plug (minus) should be connected to the green/yellow plug.
- By this way the power supply source connected at the rear side of the simulator might be grounded.
- All measuring facilities are available if
 - it is not possible to ground the "MINUS" pole and therefore the voltmeter cannot indicate the DC voltage.
 - the phase indication led at the EUT supply input are not glowing
 - there is no signal at the "CRO U" output.

11.7. Test setup and accessories


11.7.1. Transformer type V4780

The transformer shall be used to generate under-voltages in ac power supply systems. According to the IEC 61000-4-11 and the EN 50081-2 voltage dips shall be generated as shown in fig. below. Different test levels are recommended

11.7.1.1. Voltage interruptions (DIP)

Voltage interruptions will cause a reduction of the power supply voltage for a certain period of time. Three different test levels are required:

- Voltage dip by 100% to 0% of the nominal voltage for 10ms or. ½ period
- Voltage dip by 100% to 0% of the nominal voltage for 20ms respectively 1 period
- Voltage dip by 60% to 40% of the nominal voltage for 200ms respectively 10 periods
- Voltage dip by 30% to 70% of the nominal voltage for 500Ns respectively 25 periods
- Voltage dip by 20% to 80% of the nominal voltage for 5000ms respectively 250 periods



Standard voltage dips



V 4780 S2 with automatic tap control

The transformer is an accessory to the following devices

- UCS 500Nx, PFS 500

11.7.1.2. Device models V 4780

V4780	250V 16A, manual control	
V4780 S1	250V 16A manual control	additional tap at 120%
V4780 S2	250V 16A, automatic control	
V4780 S3	250V 32A, manual control	

11.7.1.3. Control V4780 S2

The V4780 S2 is controlled through the analogue input (0...10Vdc). The control circuit switches to the related tap, 40%, 70% or 80%, proportional to the applied dc reference voltage (0...10V dc) to the output PF2.

If the reference dc voltage is out of the tolerance ($\pm 0.25V$), the control will not switch to any tap to the PF2 output.

Operating with ramps the control circuit will not select a tap, if the ramp (0-100%) is shorter than approx. 4s. Programming longer ramps, each tap will switch on and off when the reference is in the valid range.

Voltage taps	DC reference voltage
80% of Unom	8.00V $\pm$ 0.25V
70%	7.00V $\pm$ 0.25V
40%	4.00V $\pm$ 0.25V

Settings on UCS for V4780 S2

The UCS must be matched to the 0-10V input of the V4780. Therefore a **V4780 must be configured as a motor variac**. For setting **V** and **Vn** must set to the same value in menu "Setup Main Voltage to high" which is the value of the voltage of your power supply.

Setup: **F7**- Service/ **F3**-Setup/ **F6** Set voltage low/high/ **F2** Setup Main Voltage to high 230V

Settings

Example for 230V mains
Example for 100V mains

V	Vn	CH
230V	230V	1
100V	100V	1

The Motorvariac must be operated in **F3 Motorvariac high** (control voltage DC out= 0-10V)

11.7.1.4. Technical Data V4780

Design Tapped auto-transformer with 40% , 70%, 80%, 100 % output voltage

Input:

Voltage Uin: max. 250V
 Frequency 50/60Hz
 Tap selection manually (V4780) banana plugs for 40%, 70%, 80%
 Remote control 0.10V dc (V4780 S2) for 40%, 70%, 80%

Output:

Voltage tap [% Unom]
 120% (V4780 S1)
 100%
 80%
 70%
 40%

V4780, S1, S2

V4780 S3

Current I _{max} .	16A	32A
Power	4.1 kVA	8.2 kVA
Fuse	2x 16A	2x 35A

Weights and measures


Dimensions	95 x 170 x 190 mm (H x B x T)	200 x 170 x 190 mm (H x B x T)
Weights	ca. 7 kg	ca. 14 kg
Temp Ambiance	10°C - 35°C	10°C - 35°C

11.7.1.5. Setup V4780


The output voltages are available at safety banana plugs. For safety reasons the related safety cables shall be used.

The power supply input is realized with a power connector for L, N and PE. The voltage shall be 100% of the nominal voltage V_n.

Connection V 4780 / V4780 S2



Connection V4780 S1




11.7.2. Motor variac type MV 2616

The motor variac can be used to simulate power supply failures as under-voltages, voltage interruptions and voltage variations. The basic standard IEC 61000-4-11 and the generic standard EN 50081-2 are specifying these phenomena.

11.7.2.1. Voltage dips / interruptions

Voltage interruptions will cause a reduction of the power supply voltage for a certain period of time. Three different test levels are required:

- Voltage dip by 100% to 0% of the nominal voltage for 10ms or. ½ period
- Voltage dip by 100% to 0% of the nominal voltage for 20ms respectively 1 period
- Voltage dip by 60% to 40% of the nominal voltage for 200ms respectively 10 periods
- Voltage dip by 30% to 70% of the nominal voltage for 500Ns respectively 25 periods
- Voltage dip by 20% to 80% of the nominal voltage for 5000ms respectively 250 periods




The unit has to be connected at the rear part of the equipment. For connection safety laboratory cables shall be used.

11.7.2.2. Voltage variation


Additionally it is possible to drive certain functions of variation, which also are required in IEC 61000-4-11. These functions can easily be programmed within the simulators itself or within the related windows software ISMIEC

V2	Test level [%U1]:	40%, 0%
tf	Time for decreasing voltage [sec]	$2 \pm 20\%$
t1	Time at retained voltage [sec]	$1 \pm 20\%$
tr	Time for increasing [sec]	$2 \pm 20\%$



For new FDIS IEC 61000-4-11 (2004) use a new procedure for voltage variation, who simulate a voltage dip during a motor start.


The motor variac will be set previously to the voltage V_2 . The switch to PF2 happens in the UCS 500. Then the motor variac increase the voltage controlled by the UCS. After t_i the voltage change back to PF1



The speed of the voltage variation depends on the max. speed of the motorvariatic and the control setting of the integral action controller. The behavior can be influenced by the parameter $V_{nominal}$. Setting in the setup menu Setup / F5 Voltage setting.

The user can optimize his setting for the test.

$V_n = V_{max}$ of motorvariatic	Red curve the voltage rising is too fast.
$V_n = 110\%$ of $V_{nominal}$	Green curve optimum setting
$V_n = V_{nominal}$	Blue curve the voltage regulation is too slow.



11.7.2.3. Technical data MV 2616**Input:**

Voltage Vin: max. 250V
Frequency 50/60Hz

Output

Voltage Vout: 0 - 260V for channel PF2
additionally Vout=Vin for channel PF1
Current max: 16A
Power 0 - 4.1 kVA

**Control**

Main switch On/Off for the output voltages
Control voltage analogue 0 - 10V DC for 0-260V output voltage
Time 0..100% < 2s

Dimensions and weight

Dimensions 19" 6HE 266x485x400mm (HxBxT)
Weight app 27 kg
Power supply 115/230V
Fuse 20A (PF1), 20A (PF2)
Environment Tmax 40°C

11.8. 50/60Hz Magnetic Field as per IEC 61000-4-8

Magnetic field standard routine IEC 61000-4-8						
<- ->		O 5 A/m		O 01:00 min		
START		O H/T				
F1	F2	F3	F4	F5	F6	F7

With the inc knob the values for the magnetic field strength and test duration can be changed. The actual parameter is indicated by a blinking circle.

Test setup




For magnetic field testing the power mains input at PF1 shall be disconnected.; 230V/16A.

The voltage V is adjusted with a variac as long as the required antenna current is available and the related H field is generated in the center of the magnetic field antenna.

The variac, type MV 2616 may be controlled automatically via the test generator. Any equivalent variac available in the lab can be used to control the current manually. Please take care that the variac has a sufficient current capability.

For more detailed information the operator can require an additional manual especially for magnetic field testing. This manual is part of the delivery of magnetic field testing accessories.

Test setup with MC 2630 for H-Fields up to 30A/m




Schematics and Test setup with UCS500Nx, MV 2616, MC 2630 and MS 100N


Option for required magnetic field tests as per IEC 61000-4-8

- External motor variac **MV 2616**
- External Magnetic field antenna **MS 100N**
- External current transformer **MC 2630** to test 1, 3, 10 and 30A/m levels

Test setup with MC 26100 for H-Fields up to 1000A/m



Schematics



Test setup

Schematics and Test setup with UCS500Nx, MV 2616, MC 26100 and MS 100N

Option for required magnetic field tests as per IEC 61000-4-8

- External motor variac **MV 2616**
- External Magnetic field antenna **MS 100N**
- External current transformer **MC 26100** to test 100 to 1000A/m levels

12. Ringwave Immunity as per IEC 61000-4-12

Ringwave Module 0.5 μ s – 100kHz

12.1. Operation

The menu offers different test routines for ring wave testing.

Ring wave
F1 : Quick Start


F1 Quick Start

Easy and fast online-operation of the equipment.

12.1.1. Quick Start

Easy and very fast operation of all standard functions of the equipment. The latest simulator settings are stored automatically and will be recalled when Quick Start is next selected.

Ring wave				Quick start		
V	=	2000 V	Imp	=	12 Ohm	
A	=	0 dgr	+/-	=	+	
cpl	=	L+N-PE	tr	=	1s	
tri	=	Auto	n	=	endl	
START CHANGE						
F1	F2	F3	F4	F5	F6	F7



Press **START** and the test routines begin to work.

Press **CHANGE** and the actual parameters can be changed.

All function keys except F2 (manual trigger) can **Stop** the test routine.

Page 3 (START)

Ring wave			Quick start			
V	=	2000 V	Imp	=	12 Ohm	
A	=	0 dgr	+/-	=	+	
cpl	=	L+N-PE	tr	=	1s	
tri	=	Auto	n	=	endl	
USet = 2000V			U = + 2000V		Counter	
STOP			I = + 0A		0000043	
F1	F2	F3	F4	F5	F6	F7

The user can select the parameter with the related function key and can change the value with the knob. The cursor allows the user to define the value of the digit which should be changed (fast or slow change).

Pressing the ESC button will bring the user back to the previous level from where the test can be restarted with new levels. After restart the actual test time is displayed. All functions keys except F2 (MAN TRIGGER) can stop the test routine. The latest setting will be displayed.

Any pressing of a function key will indicate the functions START, CHANGE or CONTINUE. F3 will continue the same test routine. Also the test time will continue running. If the user selects at first START or CHANGE the test will be stopped completely.

Page 3 (CHANGE)

Ring wave					Quick start	
Voltage	V	:	250V	-	6000V	
angle	A	:	0dgr	-	360dgr	
Events	n	:	1	-	30000	
Repetition	Rep	:	2s	-	999s	
V	Imp	A	+/-	cpl	tr	
250	12 Ohm	0	+	L+N+PE	1	1/2
F1	F2	F3	F4	F5	F6	F7

Note: At polarity setting ALT it is necessary to double the number of impulses. Example n=2 => one impulse positive and one impulse negative.

12.2. Ring wave pulse generation

Discharge switch:

The discharge switch is a highly reproducible semiconductor switch.


12.3. Coupling/decoupling network

The coupling network has to couple the interference pulses to the lines of a power supply system (AC or DC). Capacitive coupling is the specified coupling mode for surge testing.

12.3.1. Coupling to ac/dc power supply lines

The surge generator UCS 500 has an integrated coupling network in accordance with IEC 61000-4-12. It must be possible to test with different coupling modes:

Line	→	GND or
Neutral	→	GND or
L + N	→	GND or
Line	→	Neutral



The release of the surge pulses is mostly related to a certain phase angle.

The surge pulses are synchronized to the input signal at the rear Sync-connector.

Attention: The decoupling part of the coupling/decoupling network includes some capacitors for filtering of 20μF related to protective earth (chassis of the generator). This is to conform with the requirement of IEC 61000-4-5 concerning attenuation of the surge transients in direction to the power mains supply input of the CDN.

As consequence there will exist an increased current to PE (protective earth) which might be hazardous to the operator in case of a failure or wrong installation. Therefore it is very important to take the following points into account before setting the generator into full operation.:

12.4. Test set-up

According to the specifications of IEC 61000-4-12, the ring wave generator has a source impedance of 12 ohm when the simulator is coupled between the lines and protective earth.

Therefore it is important

- not to disconnect the surge simulator from protective earth (power cable)
- to have an installation where the simulator is connected via its ground reference connector to earth

1. Due to this increased current into the PE system no earth fault current protectors can be used within a surge testing area.
2. As consequence the surge generator shall be connected always to Protective Earth, even if no test is conducted.
 - via plugged in power mains supply cable including the PE wire!!!!
 - via plugged in EUT power mains supply at the rear side of the generator, including the PE wire !!!!
 - via Ground Reference Connector, screwed to the chassis of the generator.

These measures result in double safety in case of a fault

13. Telecom Surge

For Telecom pulses there are the following extensions modules:

- TSurge5 with built in module to the UCS500N5T that will be boosted up to 6HU.
- TSurge7 as an additional module to the UCS500N7

13.1. UCS 500N5T with Telecom Surge Module

UCS 500N5T with built in Telecom Surge Module 10/700us



13.2. TSurge7 Module

TSurge: Module for Telecom Surge.

10 μ s / 700 μ s as per. ITU and ETS
 9 μ s / 720 μ s gem. FCC part 68 Pulse B
 10 μ s / 700 μ s gem. IEC 61000-4-5



External TSureg7 module for UCS500N7

13.3. TSurge7 Module



- | | | |
|---|------------------------------|-----------------|
| 1 | ON LED display TSurge active | |
| 2 | Output COM plug | 15 Ω |
| 3 | Output HV plug | 15 Ω |
| 4 | Output T1...T4 | 4 x 25 Ω |

- | | |
|---|----------------------------------|
| 1 | Earth plug |
| 2 | + polarity charging |
| 3 | - polarity charging |
| 4 | COM Input TSurge – UCS |
| 5 | HV Input TSurge – UCS 500N7500N7 |
| 6 | Control TSurge |

13.4. TSurge Menu

TSurge test are possible in the menu TSurge Quickstart. This menu is only available if the CTRL cable between TSurge7 module and UCS500N7 is connected and the TSurge is detected by the UCS500N7.

The menu offers different test routines for ring wave testing.

TSURGE						
F1 : TSurge Quick Start						
F1	F2	F3	F4	F5	F6	F7

F1 Quick Start

Easy and fast online-operation of the equipment.

13.4.1. Quick Start

Easy and very fast operation of all standard functions of the equipment. The latest simulator settings are stored automatically and will be recalled when Quick Start is next selected.

TSURGE						Quick start
V	=	2000 V	+/-	=	+	
tr	=	1s	n	=	endl	
tri	=	Auto				
START CHANGE						
F1	F2	F3	F4	F5	F6	F7

Press **START** and the test routines begin to work. Press **CHANGE** and the actual parameters can be changed.

All function keys except F2 (manual trigger) can **Stop** the test routine.

Page 3 (START)

TSURGE						Quick start
V	=	2000 V	+/-	=	+	
tr	=	1s	n	=	endl	
tri	=	Auto				
Uset =	2000V					Counter
STOP						0000043
F1	F2	F3	F4	F5	F6	F7

The user can select the parameter with the related function key and can change the value with the knob. The cursor allows the user to define the value of the digit which should be changed (fast or slow change).

Pressing the ESC button will bring the user back to the previous level from where the test can be restarted with new levels. After restart the actual test time is displayed. All functions keys except F2 (MAN TRIGGER) can stop the test routine. The latest setting will be displayed.

Any pressing of a function key will indicate the functions START, CHANGE or CONTINUE. F3 will continue the same test routine. Also the test time will continue running. If the user selects at first START or CHANGE the test will be stopped completely.

Page 3 (Change)


TSURGE						Quickstart
Voltage	V	:	250V	-	6000V	
Events	n	:	1	-	30000	
Repetition	Rep	:	2s	-	999s	
U	Imp	A	+/-	cpl	tr	
250	12 Ohm	0	+	L+N+PE	1	1/2
F1	F2	F3	F4	F5	F6	F7

Note: At polarity setting ALT it is necessary to double the number of impulses. Example n=2 => one impulse positive and one impulse negative.

13.5. Coupling Network

The coupling network is responsible to couple the test pulse to the lines (ac or dc or signal lines) using single coupling resistors inside the TSurge module.


The Telecom surge is generated and coupled to the EUT as shown in the next figure.



The charging rectifier charges the both 10μF and 9μF capacitor banks in the UCS500N7 and TSurge module. Depend of the polarity the pulse forming network will be charged. The discharge switch is a highly reproducible semiconductor switch.

Pulse 10/700μs and 9/720μs as per:

- ETS 300046
- ETS 300047
- CCITT K12
- FCC part 68 for Surge B



13.6. Test Setup

Setup

The TSurge6.1 must be placed on the top of the UCS 500N7 generator.

Cabling

1. **Earth cable** UCS500N7 – TSurge7
2. **HV and COM cable** UCS500N7 – TSurge7
3. **Charging cables + / -** UCS500N7 – TSurge7
4. **Control cable CTRL** UCS500N7 – TSurge7



Test Setup UCS500N7 and TSurge7

13.7. Test pulses TSurge Modules

13.7.1. Waveshape Definitions according IEC 61000-4-5 Ed 3.0

Definition of Voltage Front Time

The voltage front time is calculated by measuring the duration between 30% and 90% (t_r) of the maximum pulse amplitude and multiplying that value by 1.67

$$T_f = t_{r30\%-90\%} \times 1.67$$

Definition of Current Front Time


The current front time is calculated by measuring the duration between 10% and 90% (t_r) of the maximum pulse amplitude and multiplying that value by 1.25

$$T_f = t_{r10\%-90\%} \times 1.25$$


Definition of Decay Time

The decay time is calculated by measuring the time from the initial rise of the waveform to the point where it decays to 50% of the maximum value. Because the time of the initial rise is difficult to measure the decay time can be calculated by adding the time between 50% of the amplitude of rising to 50% of the amplitude of decaying and 50% of the front time as defined before.

$$T_d = t_{d50\%-50\%}$$



Voltage impulse TSurge



Current impulse TSurge

13.7.2. Pulse 10 / 700 μ s as per IEC 61000-4-5**Voltage verification**

Test level : 4000 V (for N5 type max. 5000V; respectively 7000V for N7 Type).
Pulse : 10 / 700 μ s open circuit voltage waveshape
Output : on 25 Ω output (internal 40 Ω (15 Ω + 25 Ω))
Load : open circuit

Tolerances no load

	U peak	Tf	Td
pulse 10 / 700 μ s	2000 V +/- 10%	10 μ s +/- 30%	700 μ s +/- 20%

Current verification

Test level : 4000 V (for N5 type max. 5000V; respectively 7000V for N7 Type).
Pulse : 5 / 320 μ s short circuit current wave shape
Output : on 25 Ω output (internal 40 Ω (15 Ω + 25 Ω))
Load : short circuit

Tolerances

	I peak	Tf	Td
short circuit	100 A +/- 10%	5 μ s +/- 20%	320 μ s +/- 20%

13.7.3. Pulse 9 / 720 μ s as per FCC**Voltage verification**

Test level : 2000 V (for N5 type max. 5000V; respectively 7000V for N7 Type)
Pulse : 9 / 720 μ s open circuit voltage wave shape
Output : on 25 Ω output (internal 40 Ω (15 Ω + 25 Ω))
Load : open circuit

Tolerances no load

	U peak	Tf	Td
pulse 9 / 720 μ s	2000 V +/- 10%	9 μ s +/- 30%	720 μ s +/- 20%

Current verification

Test level : 2000 V (for N5 type max. 5000V; respectively 7000V for N7 Type).
Pulse : 5 / 330 μ s short circuit current wave shape
Output : on 25 Ω output (internal 40 Ω (15 Ω + 25 Ω))
Load : short circuit

Tolerances

	I peak	Tf	Td
short circuit	50 A +/- 10%	5 μ s +/- 20%	330 μ s +/- 20%

14. Appendix

14.1. Declaration of CE-Conformity

14.1.1. Declaration of Conformity UCS 500N5

Manufacturer: **EM TEST (Switzerland) GmbH**
Address: Sternenhofstr. 15
CH 4153 Reinach BL1
Switzerland

declares, that under its sole responsibility, the product's listed below, including all their options, are in conformity with the applicable CE directives listed below using the relevant section of the following EC standards and other normative documents.

Product's name: Ultra compact generator
Model Number(s) UCS 500N5

Low Voltage Directive 2014/35/EU

Standard to which conformity is declared:

EN 61010-1:2011 Safety requirements for electrical equipment for measurement, control, and laboratory use.

EMC Directive 2014/30/EU

Standard(s) to which conformity is declared:

EN 61326-1:2013 Electrical equipment for measurement, control and laboratory use
(Requirements for devices to use in industrial area.)

EN 61000-3-2:2014 Limits for harmonic current emissions

EN 61000-3-3:2013 Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems.

The purpose of this instrument is the generation of defined interference signals for EMI immunity testing. Depending on the arrangement of the test rig, the configuration, the cabling and the properties of the EUT itself, a significant amount of electromagnetic radiation may result that could also affect other equipment and systems. The user himself or herself is ultimately responsible for the correct and controlled operation of the rig. In case of doubt, the tests should be carried out in a Faraday cage.

European representative
AMETEK CTS Germany GmbH
Lünenerstr. 211
D 59174 Kamen
Tel: +49 (0) 2307 / 26070-0
Fax: +49 (0) 2307 / 17050



By A. Gerstner
General manager
Place Kamen, Germany
Date 13. December 2016

Manufacturer
EM TEST (Switzerland) GmbH
Sternenhofstr. 15
CH 4153 Reinach
Tel: +41 61-7179191
Fax: +41 61-7179199



A. Burger
Design and Research
Reinach BL, Switzerland
25. February 2016

14.1.2. Declaration of Conformity UCS 500N7

Manufacturer : **EM TEST (Switzerland) GmbH**
Address: Sternenhofstr. 15
CH 4153 Reinach BL1
Switzerland

declares, that under its sole responsibility, the product's listed below, including all their options, are in conformity with the applicable CE directives listed below using the relevant section of the following EC standards and other normative documents.

Product's name: Ultra compact generator
Model Number(s) UCS 500N7

Low Voltage Directive 2014/35/EU

Standard to which conformity is declared:

EN 61010-1:2011 Safety requirements for electrical equipment for measurement, control, and laboratory use.

EMC Directive 2014/30/EU

Standard(s) to which conformity is declared:

EN 61326-1:2013 Electrical equipment for measurement, control and laboratory use
(Requirements for devices to use in industrial area.)

EN 61000-3-2:2014 Limits for harmonic current emissions

EN 61000-3-3:2013 Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems.

The purpose of this instrument is the generation of defined interference signals for EMI immunity testing. Depending on the arrangement of the test rig, the configuration, the cabling and the properties of the EUT itself, a significant amount of electromagnetic radiation may result that could also affect other equipment and systems. The user himself or herself is ultimately responsible for the correct and controlled operation of the rig. In case of doubt, the tests should be carried out in a Faraday cage.

European representative
AMETEK CTS Germany GmbH
Lünenerstr. 211
D 59174 Kamen
Tel: +49 (0) 2307 / 26070-0
Fax: +49 (0) 2307 / 17050



By A. Gerstner
General manager
Place Kamen, Germany
Date 13. December 2016

Manufacturer
EM TEST (Switzerland) GmbH
Sternenhofstr. 15
CH 4153 Reinach
Tel: +41 61-7179191
Fax: +41 61-7179199



A. Burger
Design and Research
Reinach BL, Switzerland
25. February 2016

14.1.3. Declaration of Conformity UCS 500N5x models for one phenomenon

Manufacturer : **EM TEST (Switzerland) GmbH**
Address: Sternenhofstr. 15
CH 4153 Reinach BL1
Switzerland

declares, that under its sole responsibility, the product's listed below, including all their options, are in conformity with the applicable CE directives listed below using the relevant section of the following EC standards and other normative documents.

Product's name: Ultra compact generator
Model Number(s) UCS500N5V, UCS500N5E, UCS500N5P

Low Voltage Directive 2014/35/EU

Standard to which conformity is declared:

EN 61010-1:2011 Safety requirements for electrical equipment for measurement, control, and laboratory use.

EMC Directive 2014/30/EU

Standard(s) to which conformity is declared:

EN 61326-1:2013 Electrical equipment for measurement, control and laboratory use
(Requirements for devices to use in industrial area.)
EN 61000-3-2:2014 Limits for harmonic current emissions
EN 61000-3-3:2013 Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems.

The purpose of this instrument is the generation of defined interference signals for EMI immunity testing. Depending on the arrangement of the test rig, the configuration, the cabling and the properties of the EUT itself, a significant amount of electromagnetic radiation may result that could also affect other equipment and systems. The user himself or herself is ultimately responsible for the correct and controlled operation of the rig. In case of doubt, the tests should be carried out in a Faraday cage.

European representative
AMETEK CTS Germany GmbH
Lünenerstr. 211
D 59174 Kamen
Tel: +49 (0) 2307 / 26070-0
Fax: +49 (0) 2307 / 17050



By A. Gerstner
General manager
Place Kamen, Germany
Date 13. December 2016

Manufacturer
EM TEST (Switzerland) GmbH
Sternenhofstr. 15
CH 4153 Reinach
Tel: +41 61-7179191
Fax: +41 61-7179199



A. Burger
Design and Research
Reinach BL, Switzerland
25. February 2016

14.1.4. Declaration of Conformity UCS 500N5x models

Manufacturer : **EM TEST (Switzerland) GmbH**
 Address: Sternenhofstr. 15
 CH 4153 Reinach BL1
 Switzerland

declares, that under its sole responsibility, the product's listed below, including all their options, are conformity with the applicable CE directives listed below using the relevant section of the following EC standards and other normative documents.

Product's name: Ultra compact generator (special models)
 Model Number(s) UCS500Nx.x

Low Voltage Directive 2014/35/EU

Standard to which conformity is declared:

EN 61010-1:2011 Safety requirements for electrical equipment for measurement, control, and laboratory use.

EMC Directive 2014/30/EU

Standard(s) to which conformity is declared:

EN 61326-1:2013 Electrical equipment for measurement, control and laboratory use
 (Requirements for devices to use in industrial area.)
 EN 61000-3-2:2014 Limits for harmonic current emissions
 EN 61000-3-3:2013 Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems.

The purpose of this instrument is the generation of defined interferences signals for EMI immunity testing. Depending on the arrangement of the test rig, the configuration, the cabling and the properties of the EUT itself, a significant amount of electromagnetic radiation may result that could also affect other equipment and systems. The user himself or herself is ultimately responsible for the correct and controlled operation of the rig. In case of doubt, the tests should be carried out in a Faraday cage.

European representative
 AMETEK CTS Germany GmbH
 Lünenerstr. 211
 D 59174 Kamen
 Tel: +49 (0) 2307 / 26070-0
 Fax: +49 (0) 2307 / 17050



By A. Gerstner
 General manager
 Place Kamen, Germany
 Date 13. December 2016

Manufacturer
 EM TEST (Switzerland) GmbH
 Sternenhofstr. 15
 CH 4153 Reinach
 Tel: +41 61-7179191
 Fax: +41 61-7179199



A. Burger
 Design and Research
 Reinach BL, Switzerland
 25. February 2016

14.1.5. Declaration of Conformity TSurge 7 Module for UCS 500N7

Manufacturer : **EM TEST (Switzerland) GmbH**
Address: Sternenhofstr. 15
CH 4153 Reinach BL1
Switzerland

declares, that under its sole responsibility, the product's listed below, including all their options, are in conformity with the applicable CE directives listed below using the relevant section of the following EC standards and other normative documents.

Product's name: Telecom Surge Module
Model Number(s) TSurge7

Low Voltage Directive 2014/35/EU

Standard to which conformity is declared:

EN 61010-1:2011 Safety requirements for electrical equipment for measurement, control, and laboratory use.

EMC Directive 2014/30/EU

Standard(s) to which conformity is declared:

EN 61326-1:2013 Electrical equipment for measurement, control and laboratory use
(Requirements for devices to use in industrial area.)

EN 61000-3-2:2014 Limits for harmonic current emissions

EN 61000-3-3:2013 Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems.

The purpose of this instrument is the generation of defined interference signals for EMI immunity testing. Depending on the arrangement of the test rig, the configuration, the cabling and the properties of the EUT itself, a significant amount of electromagnetic radiation may result that could also affect other equipment and systems. The user himself or herself is ultimately responsible for the correct and controlled operation of the rig. In case of doubt, the tests should be carried out in a Faraday cage.

European representative
AMETEK CTS Germany GmbH
Lünenerstr. 211
D 59174 Kamen
Tel: +49 (0) 2307 / 26070-0
Fax: +49 (0) 2307 / 17050



By A. Gerstner
General manager
Place Kamen, Germany
Date 13. December 2016

Manufacturer
EM TEST (Switzerland) GmbH
Sternenhofstr. 15
CH 4153 Reinach
Tel: +41 61-7179191
Fax: +41 61-7179199



A. Burger
Design and Research
Reinach BL, Switzerland
25. February 2016

14.1.6. Declaration of Conformity CNT 516

Manufacturer : **EM TEST (Switzerland) GmbH**
Address: Sternenhofstr. 15
CH 4153 Reinach BL1
Switzerland

declares, that under its sole responsibility, the product's listed below, including all their options, are in conformity with the applicable CE directives listed below using the relevant section of the following EC standards and other normative documents.

Product's name: Coupling Network Telecom
Model Number(s) CNT 516

Low Voltage Directive 2014/35/EU

Standard to which conformity is declared:

EN 61010-1:2011 Safety requirements for electrical equipment for measurement, control, and laboratory use.

EMC Directive 2014/30/EU

Standard(s) to which conformity is declared:

EN 61326-1:2013 Electrical equipment for measurement, control and laboratory use
(Requirements for devices to use in industrial area.)

EN 61000-3-2:2014 Limits for harmonic current emissions

EN 61000-3-3:2013 Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems.

The purpose of this instrument is the generation of defined interference signals for EMI immunity testing. Depending on the arrangement of the test rig, the configuration, the cabling and the properties of the EUT itself, a significant amount of electromagnetic radiation may result that could also affect other equipment and systems. The user himself or herself is ultimately responsible for the correct and controlled operation of the rig. In case of doubt, the tests should be carried out in a Faraday cage.

European representative
AMETEK CTS Germany GmbH
Lünenerstr. 211
D 59174 Kamen
Tel: +49 (0) 2307 / 26070-0
Fax: +49 (0) 2307 / 17050



By A. Gerstner
General manager
Place Kamen, Germany
Date 13. December 2016

Manufacturer
EM TEST (Switzerland) GmbH
Sternenhofstr. 15
CH 4153 Reinach
Tel: +41 61-7179191
Fax: +41 61-7179199



A. Burger
Design and Research
Reinach BL, Switzerland
25. February 2016

14.1.7. Declaration of Conformity Tapped Transformer

Manufacturer : **EM TEST (Switzerland) GmbH**
Address: Sternenhofstr. 15
CH 4153 Reinach BL1
Switzerland

declares, that under its sole responsibility, the product's listed below, including all their options, are in conformity with the applicable CE directives listed below using the relevant section of the following EC standards and other normative documents.

Product's name: Tapped transformer
Model Number(s) V 4780,
V 4780S1

Low Voltage Directive 2014/35/EU

Standard to which conformity is declared:

EN 61010-1:2011 Safety requirements for electrical equipment for measurement, control, and laboratory use.

EMC Directive 2014/30/EU

Standard(s) to which conformity is declared:

EN 61326-1:2013 Electrical equipment for measurement, control and laboratory use
(Requirements for devices to use in industrial area.)

EN 61000-3-2:2014 Limits for harmonic current emissions

EN 61000-3-3:2013 Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems.

The purpose of this instrument is the generation of defined interference signals for EMI immunity testing. Depending on the arrangement of the test rig, the configuration, the cabling and the properties of the EUT itself, a significant amount of electromagnetic radiation may result that could also affect other equipment and systems. The user himself or herself is ultimately responsible for the correct and controlled operation of the rig. In case of doubt, the tests should be carried out in a Faraday cage.

European representative
AMETEK CTS Germany GmbH
Lünenerstr. 211
D 59174 Kamen
Tel: +49 (0) 2307 / 26070-0
Fax: +49 (0) 2307 / 17050




By A. Gerstner
General manager
Place Kamen, Germany
Date 13. December 2016

Manufacturer
EM TEST (Switzerland) GmbH
Sternenhofstr. 15
CH 4153 Reinach
Tel: +41 61-7179191
Fax: +41 61-7179199




A. Burger
Design and Research
Reinach BL, Switzerland
25. February 2016


14.2. UCS 500N - General Diagram



14.3. Main diagram control connection



14.4. Main diagram high voltage connection



14.5. CNT 508N

The CNT 508N is a coupling network for coupling surge pulses to 8 lines via a 25Ω resistor. Depends from where the pulse is adapted different waveshapes can be applied to the EUT.



14.5.1. Operating elements



- 1 HV Output T1...T8
- 2 COM output

- 3 Earth bolt
- 4 COM input
- 5 HV input

14.5.2. Technical data:

As per IEC 61000-4-5 and other relevant standards

Pulse	10/700μs or 1.2/50μs
Open circuit voltage	160V – 7,000V ±10%
Serial resistor per output	25 Ω ±10%
Number of parallel HV outputs	8
Number of COM outputs	2


Coupling

Channels	8 channels in parallel T1 to T8 with 25Ω each
----------	---


Dimensions

Housing	19", 3HU, 448x250x143mm
Weight	6.05 kg

14.5.3. Main diagram



14.5.4. Test Setup



14.5.5. Accessories:



Screw set

Earth cable



HV cable

COM cable




8 (red) + 2 (black) EUT cables 2m

14.6. CNT 516

The CNT 516 is a coupling network for coupling surge pulses to 16 lines via a 25Ω resistor. Depends from where the pulse is adapted different waveshapes can be applied to the EUT.



14.6.1. Operating elements



- 1 HV Output T1...T16
- 2 COM output

- 3 Earth bolt
- 4 COM input
- 5 HV input

14.6.2. Technical data:

As per IEC 61000-4-5 and other relevant standards

Pulse	10/700 μ s or 1.2/50 μ s
Open circuit voltage	160V – 7,000V $\pm 10\%$
Serial resistor per output	25 Ω $\pm 10\%$
Number of parallel HV outputs	16
Number of COM outputs	3


Coupling

Channels	16 channels in parallel T1 to T16 with 25 Ω each
----------	---


Dimensions

Housing	19", 3HU, 448x250x143mm
Weight	6.25kg

14.6.3. Main diagram



14.6.4. Test Setup



14.6.5. Accessories:



Screw set

Earth cable



HV cable

COM cable



16 (red) + 3 (black) EUT cables 2m

14.7. USB interface

USB interface “USB B” connector. For data transfer a USB interface is available. The internal RS 232 interface is converted to USB standard. Therefore, the user must set the same baud rate in the device and control software.

Using the USB interface the user can have EMC problems during burst tests. Therefore, a high quality USB cable (USB 2.0 standard) must be used.

The experience shows that usually the computer USB port is disturbed by interference's. The ferrite FER-USB reduces additional the interferences on the USB cable.

If there are still interferences, the whole test set-up with the wiring has to be reconsidered.

USB cable setup

The USB cable must be above ground with a distance of at least 10 cm. Otherwise the cable can be an antenna for the common mode burst pulses and the communication may be influenced.

EM test provides a suitable ferrite as accessories under the name UBS FER.

Best results are reached with 8 turns.

